



ECMPS Client Tool

Version 1.* 2022 Q1

Emissions Evaluation Report

March 25, 2022 04:46 PM

Facility Name: Chalk Point

Facility Details

Facility ID (ORISPL): 1571
Monitoring Plan Location IDs: **GT5
State: MD
County: Prince George's County
Year/Quarter: 2020 Q4
Total Hours: 2208

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

Hourly Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
**GT5	INFORM	HOURDHV-47-C	Warning: Based on the BeginDate in your NOXR Default record in your monitoring plan, the LME Unit Default Test(s) that established the default NOx emission rate for Fuel Code PNG may have expired. Unit Default Tests must be performed every five years. If your test has expired, you need to use a Part 75 default NOx emissions rate until you perform a new unit-and-fuel-specific default test. You will need to put an end date on your existing NOXR default records in your monitoring plan, and add a new NOXR default record based on the Part 75 default value.	10/27/2020 10	10/27/2020 20	11