

# **Facility Name: El Centro**

### **Facility Details**

Facility ID (ORISPL): 389
Monitoring Plan Location IDs: 2-2
State: CA

County: Imperial County
Year/Quarter: 2021 Q2
Total Hours: 2184

#### **Evaluation Results**

#### **General Errors**

Severity	Check Code / Result	Result Message
INFORM		The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

## **Hourly Data Errors**

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
2-2	INFORM		Warning: The ParameterValueForFuel reported in the HPFF record for HI for FuelCode DSL exceeds the MaximumHourlyHeatInputCapacity reported in the Unit Capacity record in your monitoring plan. Sources are required to periodically (at least once annually) evaluate the appropriateness of maximum values in the monitoring plan and make proper adjustments when necessary. You should investigate the cause of these exceedances and determine whether an adjustment to the MaximumHourlyHeatInputCapacity reported in your monitoring plan is necessary.	06/08/2021 09	06/08/2021 09	1
				06/08/2021 12	06/08/2021 13	2
				06/09/2021 09	06/09/2021 09	1
			Warning: The AdjustedHourlyValue reported in the DHV record for HI is in excess of the maximum value listed in the monitoring plan. Sources are required to periodically (at least once annually) evaluate the appropriateness of these maximum values in the monitoring plan and make proper adjustments when necessary. Adjustments may include the need to update Span, Default, and/or Unit Capacity values. You should investigate the cause of these exceedances and determine whether adjustments to your monitoring systems or monitoring plan are necessary.	06/08/2021 12	06/08/2021 12	1
				06/09/2021 09	06/09/2021 09	1