



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

October 7, 2022 11:45 PM

Facility Name: NCEMC Anson Plant

Facility Details

Facility ID (ORISPL): 56249
Monitoring Plan Location IDs: ES1-B
State: NC
County: Anson County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
ES1-B	FF2LTST	FF2L-Q12019-02A-2 2019 Q1	02A/GAS	CRIT1	FF2LTST-11-A	You did not provide TestResultCode, which is required for this test.
				INFORM	FF2LTST-2-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		FF2L-Q12020-02A-2 2020 Q1	02A/GAS	CRIT1	FF2LTST-7-A	The value -1 in the field NumberOfHoursExcludedCofiring for this test is not within the range of valid values. This value must be greater than or equal to zero.
				INFORM	FF2LTST-2-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		FF2L-Q12021-02A-2 2021 Q1	02A/GAS	CRIT1	FF2LTST-5-E	The TestResultCode of the fuel flow-to-load test indicates a failing test, but the AverageDifference indicates a passing test.
					FF2LTST-6-C	The NumberOfHoursUsed was less than 168 which is the minimum required to complete the quarterly fuel flow-to-load test.
				INFORM	FF2LTST-2-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		FF2L-Q22019-02A-2 2019 Q2	02A/GAS	CRIT1	FF2LTST-10-A	You did not provide TestReasonCode, which is required for this test.
				INFORM	FF2LTST-2-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		FF2L-Q22020-02A-2 2020 Q2	02A/GAS	CRIT1	FF2LTST-4-B	The TestBasisCode is inconsistent with the data submitted in the associated fuel flow-to-load baseline data.
				INFORM	FF2LTST-2-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		FF2L-Q22021-02A-2 2021 Q2	02A/GAS	CRIT1	FF2LTST-3-A	You did not provide TestBasisCode, which is required for this test.
					FF2LTST-6-C	The NumberOfHoursUsed was less than 168 which is the minimum required to complete the quarterly fuel flow-to-load test.
				INFORM	FF2LTST-2-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.

Facility Name: NCEMC Anson Plant

QA/Cert Test Evaluation Report

Facility ID (ORISPL): 56249

October 7, 2022 11:45 PM

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
ES1-B	FF2LTST	FF2L-Q32019-02A-2 2019 Q3	02A/GAS	CRIT1	FF2LTST-9-A	The value -1 in the field NumberOfHoursExcludedLowRange for this test is not within the range of valid values. This value must be greater than or equal to zero.
				INFORM	FF2LTST-2-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		FF2L-Q32021-02A-2 2021 Q3	02A/GAS	INFORM	FF2LTST-2-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
				INFORM	FF2LTST-2-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		FF2L-Q42018-02A-2 2018 Q4	02A/GAS	CRIT1	FF2LTST-12-A	The total number of hours used in the fuel flow-to-load or GHR analysis and the number of hours excluded exceed the total number of hours in the quarter.
				INFORM	FF2LTST-2-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		FF2L-Q42019-02A-2 2019 Q4	02A/GAS	CRIT1	FF2LTST-8-A	The value -1 in the field NumberOfHoursExcludedRamping for this test is not within the range of valid values. This value must be greater than or equal to zero.
				INFORM	FF2LTST-2-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		FF2L-Q42020-02A-2 2020 Q4	02A/GAS	CRIT1	FF2LTST-6-A	The value -1 in the field NumberOfHoursUsed for this test is not within the range of valid values. This value must be greater than or equal to zero.
				INFORM	FF2LTST-2-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.