



ECMPS Client Tool

Version 1.* 2022 Q2

Emissions Evaluation Report

August 16, 2022 01:48 PM

Facility Name: Lincoln Combustion Turbine

Facility Details

Facility ID (ORISPL): 7277
Monitoring Plan Location IDs: 1
State: NC
County: Lincoln County
Year/Quarter: 2021 Q1
Total Hours: 2160

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

Hourly Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
1	CRIT1	HOURAE-2-A	You did not report an HPFF record for NOXR to report the NOx emission rate for individual fuels.	01/28/2021 07	01/28/2021 07	1
		HOURAE-5-E	You reported NOXE MonitoringSystemID 410 in the HPFF record for NOXR, but the FuelCode of this system is not equal to FuelCode DSL in the associated HFF record.	01/28/2021 09	01/28/2021 09	1
		HOURAE-8-A	You reported a SegmentNumber in the HPFF or DHV record for NOXR for FuelCode PNG. This field should be blank when OperatingConditionCode is E.	01/28/2021 09	01/28/2021 09	1
		HOURAE-9-F	The ParameterValueForFuel reported in the HPFF record for NOXR for FuelCode PNG is inconsistent with the value recalculated from the Appendix E curve.	01/28/2021 09	01/28/2021 09	1
		HOURAE-13-B	You reported ParameterValueForFuel in the HPFF record for NOXR that is not rounded to the appropriate precision for that parameter.	02/02/2021 06	02/02/2021 06	1
		HOURAE-14-A	The ParameterUOMCode reported in the HPFF record for NOXR for FuelCode PNG is missing or invalid. The value should be "LBMMBTU".	02/02/2021 08	02/02/2021 08	1
	NONCRIT	HOURAE-4-A	You reported SampleTypeCode in the HPFF record for NOXR for FuelCode PNG. This data should be blank.	01/28/2021 08	01/28/2021 08	1
	INFORM	HOURAE-9-H	The ParameterValueForFuel in the HPFF record for NOXR for FuelCode DSL could not be recalculated due to errors listed above.	01/28/2021 09	01/28/2021 09	1

Facility Name: Lincoln Combustion Turbine

Emissions Evaluation Report

Facility ID (ORISPL): 7277

August 16, 2022 01:48 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
1	INFORM	HOURCV-16-A	The AdjustedHourlyValue in the DHV record for NOX could not be recalculated due to errors listed above.	01/28/2021 07	01/28/2021 07	1
				01/28/2021 09	01/28/2021 09	1
		HOURCV-41-A	The AdjustedHourlyValue in the DHV record for NOXR could not be recalculated due to errors listed above.	01/28/2021 07	01/28/2021 07	1
				01/28/2021 09	01/28/2021 09	1

Summary Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message
1	CRIT1	HOURAGG-7-E	The CurrentReportingPeriodTotal in the Summary Value record for NOXR could not be recalculated because of errors listed above.
		HOURAGG-8-E	The CurrentReportingPeriodTotal in the Summary Value record for NOXM could not be recalculated because of errors listed above.