



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

November 22, 2022 08:20 PM

Facility Name: Barry

Facility Details

Facility ID (ORISPL): 3
State: AL
County: Mobile County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
5	RATA	202003300811ADA 03/30/2020 13:53	ADA/SO2	INFORM	AETB-9-C	You reported an ExamDate that is more than five years prior to the date of the test for Benjamin A. Chalk. AETB exams expire in five years.
					RATA-49-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
					RATA-132-A	You have reported more than 3 decimal places for ConfidenceCoefficient, MeanCEMValue, MeanDifference, MeanRATAReferenceValue, and StandardDeviationDifference, which is not permitted by Part 75.
		202003301130ADE 03/30/2020 17:48	ADE/HG	CRIT1	AETB-4-A	You did not provide AETBName, which is required for a A. a.
					AETB-5-A	You did not provide AETBPhoneNumber, which is required for a A. a.
					AETB-6-A	You did not provide AETBEmail, which is required for a A. a.
					AETB-7-A	You did not provide ProviderName, which is required for a A. a.
					AETB-8-A	You did not provide ProviderEmail, which is required for a A. a.
					AETB-9-A	You did not provide ExamDate, which is required for a A. a.
					AETB-10-B	Air Emissions Testing Records are not required for Hg, HCl, HF, or ST tests.
				INFORM	RATA-49-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.