



ECMPS Client Tool

Version 1.* 2022 Q2

Emissions Evaluation Report

July 1, 2022 11:38 AM

Facility Name: Sooner

Facility Details

Facility ID (ORISPL): 6095
Monitoring Plan Location IDs: 2
State: OK
County: Noble County
Year/Quarter: 2021 Q4
Total Hours: 2208

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

QA Status Errors

Unit/Stack/ Pipe	Category Description	Severity	Check Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
2	Hg System Integrity Status Evaluation	CRIT1	OOC-Event	You reported a QA Certification Event record for QACertEventCode 141 QACertEventDate 12/14/2021 for Component ID 240, and have not yet performed the required recertification tests.	12/26/2021 00	12/26/2021 02	3
			OOC-Expired	The prior weekly system integrity test for Component ID 240 on 10-07-2021 at 07:29 has expired.	12/29/2021 03	12/29/2021 06	4
					12/29/2021 10	12/29/2021 10	1
			OOC-No Prior Test	You did not report a prior weekly system integrity test for Component ID LK8 during the reporting period. Any weekly system integrity that may have been completed in a prior reporting period has expired.	10/18/2021 00	10/18/2021 18	19
					10/21/2021 14	10/22/2021 07	18
			OOC-Test Failed	The prior weekly system integrity test for Component ID 240 completed on 11-11-2021 at 09:50 failed.	12/08/2021 00	12/08/2021 08	9
					11/11/2021 13	11/13/2021 05	41
					11/13/2021 08	11/15/2021 20	61
					11/19/2021 18	11/19/2021 20	3
			OOC-Test Has Critical Errors	The prior weekly system integrity test for Component ID 240 completed on 11-19-2021 at 22:33 has critical errors.	11/19/2021 22	11/22/2021 08	59

Hourly Data Errors

Facility Name: **Sooner**

Emissions Evaluation Report

Facility ID (ORISPL): **6095**

July 1, 2022 11:38 AM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
2	CRIT1	EMWSI-8-A	For Location 2, Component 240 and Type HG at 11/19/2021 10:00:00 PM, the TestResultCode is not consistent with the test result recalculated from the reported records.	11/19/2021 22	11/19/2021 22	1
		EMWTS-9-A	You did not provide a Test Result Code, which is required, for Location 2, Component 240 and Type HG at 11/19/2021 10:00:00 PM.	11/19/2021 22	11/19/2021 22	1

Audit Results

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message
2	INFORM	EMAUDIT-1-B	You have reported hourly data using Like Kind component 'LK8' for 286 hour(s) this year. Please be aware that the use of like kind monitors is limited to less than 720 hours on an annual basis.