



ECMPS Client Tool

Version 1.* 2022 Q2

Emissions Evaluation Report

September 13, 2022 03:05 PM

Facility Name: Harrington Station

Facility Details

Facility ID (ORISPL): 6193
Monitoring Plan Location IDs: 061B
State: TX
County: Potter County
Year/Quarter: 2021 Q4
Total Hours: 2208

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.
	HOURGEN-14-A	You reported one or more daily calibration tests that will not fulfill your daily calibration testing requirement, because these tests were performed while the unit was not operating and you have not reported a prior online-offline calibration demonstration. These tests have been assigned a CalculatedTestResult of "IGNORED", and they can be viewed on the Daily Calibration tab of the View Detailed Emissions Screen. If you intend to use offline tests to fulfill your daily calibration testing requirement, you must conduct an online-offline calibration demonstration.
	HOURGEN-16-A	You reported one or more daily interference checks that will not fulfill your daily testing requirement for your stack flow monitors, because these tests were performed while the unit was not operating. These tests have been assigned a CalculatedTestResult of "IGNORED". They can be viewed on the Other Daily Tests tab of the View Detailed Emissions Screen.