



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

October 11, 2022 02:44 PM

Facility Name: NCEMC Anson Plant

Facility Details

Facility ID (ORISPL): 56249
State: NC
County: Anson County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
ES2-A	FF2LBAS	FF2B-Q32016-03A-5 10/26/2016 14	03A/GAS	CRIT1	FF2LBAS-14-B	The number of hours excluded in the baseline data collection period exceeds the number of available clock hours in the period.
				CRIT2	FF2LBAS-5-A	The baseline period exceeds the 4 quarters allowed for the collection of fuel flow-to-load baseline data.
				INFORM	FF2LBAS-2-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		FF2B-Q32021-03A-5 08/10/2021 14	03A/GAS	CRIT1	FF2LBAS-4-A	You reported both a Fuel flow-to-load ratio and a GHR value. Since only one methodology can be used, this record is invalid.
				INFORM	FF2LBAS-2-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.