



ECMPS Client Tool

Version 1.* 2022 Q1

Emissions Evaluation Report

March 25, 2022 03:09 PM

Facility Name: Higginsville Municipal Power Plant

Facility Details

Facility ID (ORISPL): 2131
Monitoring Plan Location IDs: 4A
State: MO
County: Lafayette County
Year/Quarter: 2021 Q4
Total Hours: 2208

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

Hourly Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
4A	CRIT1	HOURDHV-37-A	You did not report a single, active, valid default record for MHHI in your monitoring plan.	10/08/2021 20	10/11/2021 12	65
				10/13/2021 08	10/13/2021 20	13
				10/14/2021 23	10/15/2021 19	21
				10/19/2021 23	10/20/2021 05	7
				11/10/2021 16	11/12/2021 21	54
	INFORM	HOURDHV-39-D	The AdjustedHourlyValue in the DHV record for SO2M could not be recalculated because the heat input rate could not be determined for the hour.	10/08/2021 20	10/11/2021 12	65
				10/13/2021 08	10/13/2021 20	13
				10/14/2021 23	10/15/2021 19	21
				10/19/2021 23	10/20/2021 05	7
				11/10/2021 16	11/12/2021 21	54
		HOURDHV-40-A	The AdjustedHourlyValue in the DHV record for HIT could not be recalculated due to another error listed in this report.	10/08/2021 20	10/11/2021 12	65
				10/13/2021 08	10/13/2021 20	13
				10/14/2021 23	10/15/2021 19	21

Facility Name: Higginsville Municipal Power Plant

Emissions Evaluation Report

Facility ID (ORISPL): 2131

March 25, 2022 03:09 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
4A	INFORM	HOURLHV-40-A	The AdjustedHourlyValue in the DHV record for HIT could not be recalculated due to another error listed in this report.	10/19/2021 23	10/20/2021 05	7
				11/10/2021 16	11/12/2021 21	54
		HOURLHV-44-E	The AdjustedHourlyValue in the DHV record for NOXM could not be recalculated because the heat input rate could not be determined for the hour.	10/08/2021 20	10/11/2021 12	65
				10/13/2021 08	10/13/2021 20	13
				10/14/2021 23	10/15/2021 19	21
				10/19/2021 23	10/20/2021 05	7
				11/10/2021 16	11/12/2021 21	54

Summary Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message
4A	CRIT1	HOURAGG-2-E	The CurrentReportingPeriodTotal in the Summary Value record for SO2M could not be recalculated because of errors listed above.
		HOURAGG-4-E	The CurrentReportingPeriodTotal in the Summary Value record for HIT could not be recalculated because of errors listed above.
		HOURAGG-8-E	The CurrentReportingPeriodTotal in the Summary Value record for NOXM could not be recalculated because of errors listed above.