



ECMPS Client Tool

Version 1.* 2022 Q2

Emissions Evaluation Report

August 16, 2022 02:11 PM

Facility Name: Lincoln Combustion Turbine

Facility Details

Facility ID (ORISPL): 7277
Monitoring Plan Location IDs: 1
State: NC
County: Lincoln County
Year/Quarter: 2021 Q3
Total Hours: 2208

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
CRIT1	HOURGEN-8-B	The Monitoring Plan associated with this quarterly emissions file has not been evaluated. You must evaluate the Monitoring Plan for this monitoring configuration in order to complete the evaluation of this emissions file.
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

Hourly Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
1	CRIT1	HOURAE-7-A	The NOx emission rate could not be determined, because you did not report one and only one missing data default record for NORX for FuelCode PNG in your monitoring plan that was active during current hour.	08/19/2021 15	08/19/2021 15	1
		HOURAE-8-A	You reported a SegmentNumber in the HPFF or DHV record for NOXR for FuelCode PNG. This field should be blank when OperatingConditionCode is U.	08/19/2021 15	08/19/2021 15	1
	INFORM	HOURAE-9-H	The ParameterValueForFuel in the HPFF record for NOXR for FuelCode PNG could not be recalculated due to errors listed above.	08/19/2021 15	08/19/2021 15	1
		HOURCV-16-A	The AdjustedHourlyValue in the DHV record for NOX could not be recalculated due to errors listed above.	08/19/2021 15	08/19/2021 15	1
		HOURCV-41-A	The AdjustedHourlyValue in the DHV record for NOXR could not be recalculated due to errors listed above.	08/19/2021 15	08/19/2021 15	1

Summary Data Errors

Facility Name: Lincoln Combustion Turbine

Emissions Evaluation Report

Facility ID (ORISPL): 7277

August 16, 2022 02:11 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message
1	CRIT1	HOURAGG-7-E	The CurrentReportingPeriodTotal in the Summary Value record for NOXR could not be recalculated because of errors listed above.
		HOURAGG-8-E	The CurrentReportingPeriodTotal in the Summary Value record for NOXM could not be recalculated because of errors listed above.