



ECMPS Client Tool

Version 1.* 2022 Q1

Emissions Evaluation Report

March 4, 2022 12:18 PM

Facility Name: Bucksport Generation LLC

Facility Details

Facility ID (ORISPL): 50243
Monitoring Plan Location IDs: GEN4
State: ME
County: Hancock County
Year/Quarter: 2021 Q3
Total Hours: 2208

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

Hourly Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
GEN4	INFORM	HOURCV-39-G	Warning: The AdjustedHourlyValue reported in the DHV record for NOXR is in excess of the maximum value listed in the monitoring plan. Sources are required to periodically (at least once annually) evaluate the appropriateness of these maximum values in the monitoring plan and make proper adjustments when necessary. Adjustments may include the need to update Span, Default, and/or Unit Capacity values. You should investigate the cause of these exceedances and determine whether adjustments to your monitoring systems or monitoring plan are necessary.	07/06/2021 16	07/06/2021 16	1
				07/07/2021 15	07/07/2021 15	1
				07/17/2021 15	07/17/2021 15	1
				08/24/2021 16	08/24/2021 16	1
				08/25/2021 15	08/25/2021 15	1
				08/26/2021 15	08/26/2021 15	1
				09/23/2021 08	09/23/2021 09	2