



ECMPS Client Tool

Version 1.* 2022 Q2

Emissions Evaluation Report

September 9, 2022 11:29 AM

Facility Name: Harrison Power Station

Facility Details

Facility ID (ORISPL): 3944
Monitoring Plan Location IDs: 2
State: WV
County: Harrison County
Year/Quarter: 2020 Q4
Total Hours: 2208

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

Hourly Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
2	INFORM	HOURMHV-9-F	You reported an MODCCode of 10 in the MHV record for FLOW, but the PercentAvailability is greater than or equal to 90. When the PMA is greater than or equal to 90, you should only report an MODC of 10 to indicate that you used the maximum hourly value in the lookback period for the next available higher load bin, because there were no quality-assured data in the bin corresponding to the current load range. (See Part 75.33(c)(5).)	10/31/2020 15	10/31/2020 15	1