



ECMPS Client Tool

Version 1.* 2022 Q2

Emissions Evaluation Report

September 14, 2022 04:40 PM

Facility Name: Ray D Nixon

Facility Details

Facility ID (ORISPL): 8219
Monitoring Plan Location IDs: 1
State: CO
County: El Paso County
Year/Quarter: 2021 Q2
Total Hours: 2184

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

QA Status Errors

Unit/Stack/ Pipe	Category Description	Severity	Check Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
1	Daily Interference Check Status Evaluation	CRIT1	OOC-Test Failed	The prior daily interference check for Component ID 004 completed on 06/03/2021 failed.	06/03/2021 12	06/03/2021 12	1
	Stack Flow RATA Status Evaluation	CRIT1	OOC-Event	You reported a QA Certification Event record for QACertEventCode 301 QACertEventDate 06/03/2021 for SystemID 104, but you did not indicate the use of conditional data.	06/03/2021 12	06/03/2021 12	1

Hourly Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
1	CRIT1	HOURCV-7-B	The AdjustedHourlyValue reported in the DHV record for HI is inconsistent with the recalculated value.	06/03/2021 10	06/03/2021 11	2
				06/03/2021 13	06/03/2021 15	3
				06/03/2021 22	06/04/2021 14	17
		HOURCV-9-B	The AdjustedHourlyValue reported in the DHV record for SO2 is inconsistent with the recalculated value.	06/03/2021 10	06/03/2021 11	2
				06/03/2021 13	06/03/2021 15	3
				06/03/2021 22	06/04/2021 14	17

Facility Name: Ray D Nixon

Facility ID (ORISPL): 8219

Emissions Evaluation Report

September 14, 2022 04:40 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
1	CRIT1	HOURCV-19-B	The AdjustedHourlyValue reported in the DHV record for CO2 is inconsistent with the recalculated value.	06/03/2021 10	06/03/2021 11	2
				06/03/2021 13	06/03/2021 15	3
				06/03/2021 22	06/04/2021 14	17
		HOURMHV-19-G	You reported an MODCCode of 06 in the MHV record for FLOW, but the AdjustedHourlyValue does not equal average of measured hour before and measured hour after.	06/03/2021 10	06/03/2021 11	2
				06/03/2021 13	06/03/2021 15	3
				06/03/2021 22	06/04/2021 14	17

Summary Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message
1	CRIT1	HOURAGG-3-A	The CurrentReportingPeriodTotal of 135839.500 reported in the Summary Value record for CO2M for the reporting period is inconsistent with the recalculated value of 135987.8.
		HOURAGG-4-A	The CurrentReportingPeriodTotal of 1297201.000 reported in the Summary Value record for HIT for the reporting period is inconsistent with the recalculated value of 1298621.
		HOURAGG-10-C	The YearToDateTotal of 413389.700 in the Summary Value record for CO2M is inconsistent with the recalculated value of 413538.000.
		HOURAGG-14-H	The YearToDateTotal of 3943925.000 in the Summary Value record for HIT is inconsistent with the recalculated value of 3945345.000.