



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

October 14, 2022 06:00 PM

Facility Name: Bethpage Energy Center

Facility Details

Facility ID (ORISPL): 50292
State: NY
County: Nassau County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
GT2	7DAY	7DAY-Q22015-012-3 05/26/2015 01:15	012/NOX	CRIT1	SEVNDAY-9-B	The value -1.00 in the field UpscaleCalibrationError for Zero Injection Date 05/20/2015 is not within the range of valid values. This value must be greater than or equal to zero.
				INFORM	SEVNDAY-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		7DAY-Q22015-013-4 05/26/2015 01:15	013/NOX	CRIT1	SEVNDAY-10-A	You did not provide UpscaleGasLevelCode, which is required for Zero Injection Date 05/20/2015.
				INFORM	SEVNDAY-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
					SEVNDAY-16-A	The software could not evaluate the Upscale injection calculations reported for Zero Injection Date 05/20/2015, because of the errors listed above.
		7DAY-Q22015-031-4 05/26/2015 01:15	031/CO2	CRIT1	SEVNDAY-12-A	You did not provide UpscaleMeasuredValue, which is required for Zero Injection Date 05/20/2015.
				INFORM	SEVNDAY-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
					SEVNDAY-16-A	The software could not evaluate the Upscale injection calculations reported for Zero Injection Date 05/20/2015, because of the errors listed above.
		7DAY-Q22015-032-4 05/26/2015 01:15	032/CO2	CRIT1	SEVNDAY-13-B	The value -1.000 in the field ZeroReferenceValue for Zero Injection Date 05/20/2015 is not within the range of valid values. This value must be greater than or equal to zero.
				INFORM	SEVNDAY-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
					SEVNDAY-15-A	The software could not evaluate the Zero injection calculations reported for Zero Injection Date 05/20/2015, because of the errors listed above.
		7DAY-Q42015-013-1 11/15/2015 08:59	013/NOX	CRIT1	SEVNDAY-11-A	You did not provide ZeroMeasuredValue, which is required for Zero Injection Date 11/09/2015.
				INFORM	SEVNDAY-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
					SEVNDAY-15-A	The software could not evaluate the Zero injection calculations reported for Zero Injection Date 11/09/2015, because of the errors listed above.
		7DAY-Q42015-032-2 11/15/2015 08:59	032/CO2	CRIT1	SEVNDAY-14-A	You did not provide UpscaleReferenceValue, which is required for Zero Injection Date 11/09/2015.

Facility Name: Bethpage Energy Center

QA/Cert Test Evaluation Report

Facility ID (ORISPL): 50292

October 14, 2022 06:00 PM

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
GT2	7DAY	7DAY-Q42015-032-2 11/15/2015 08:59	032/CO2	INFORM	SEVNDAY-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
					SEVNDAY-16-A	The software could not evaluate the Upscale injection calculations reported for Zero Injection Date 11/09/2015, because of the errors listed above.
		7DAY-Q42015-213-1 11/15/2015 08:59	213/NOX	CRIT1	SEVNDAY-17-F	The Zero Calibration Error reported for Zero Injection Date 11/09/2015 is inconsistent with the recalculated calibration error for the gas injection or reference signal.
				INFORM	SEVNDAY-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		7DAY-Q42015-232-2 11/15/2015 08:59	232/CO2	CRIT1	SEVNDAY-18-C	You reported a value of "1" as the Upscale APS Indicator for Zero Injection Date 11/09/2015, but you must use the standard performance specification criteria for CO2 and O2 components.
				INFORM	SEVNDAY-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.