



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

November 18, 2022 05:19 PM

Facility Name: Crystal River

Facility Details

Facility ID (ORISPL): 628
State: FL
County: Citrus County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
1GTB	CYCLE	CI1B-CHNOX-0119 01/23/2019 10:02	001/NOX	NONCRIT	CYCLE-18-E	You reported a TestResultCode of "FAILED", but the results recalculated or determined from the other reported values indicate that the test passed.
				INFORM	CYCLE-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		CI1B-CLNOX-0119 01/23/2019 10:02	001/NOX	CRIT1	CYCLE-17-A	You did not provide TotalCycleTime, which is required for this test.
				INFORM	CYCLE-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.