



# ECMPS Client Tool

Version 1.\* 2022 Q1

## Emissions Evaluation Report

April 20, 2022 12:49 PM

Facility Name: John Sevier

### Facility Details

Facility ID (ORISPL): 3405  
Monitoring Plan Location IDs: JCC1  
State: TN  
County: Hawkins County  
Year/Quarter: 2021 Q4  
Total Hours: 2208

### Evaluation Results

#### General Errors

Severity	Check Code / Result	Result Message
INFORM	<a href="#">HOURGEN-13-B</a>	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

#### Hourly Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
JCC1	CRIT1	<a href="#">HOURCV-7-B</a>	The AdjustedHourlyValue reported in the DHV record for HI is inconsistent with the recalculated value.	10/01/2021 09	10/01/2021 09	1
		<a href="#">HOURCV-16-B</a>	The AdjustedHourlyValue reported in the DHV record for NOX is inconsistent with the recalculated value.	10/01/2021 09	10/01/2021 09	1
		<a href="#">HOURMHV-16-A</a>	The UnadjustedHourlyValue reported in the MHV record for NOXC is missing or invalid.	10/12/2021 10	10/12/2021 10	1
		<a href="#">HOUROP-17-G</a>	You reported a DHV record for SO2, but you did not report any Hourly Fuel Flow records at the location.	10/01/2021 09	10/01/2021 09	1
		<a href="#">HOUROP-22-E</a>	You reported a DHV record for CO2, but you did not report any Hourly Fuel Flow records at the location.	10/01/2021 09	10/01/2021 09	1
		<a href="#">HOUROP-24-B</a>	You did not report an HFF record for the hour.	10/01/2021 09	10/01/2021 09	1
		<a href="#">HOUROP-54-A</a>	Linearity and System Integrity tests are not allowed during non-operating hours, but the begin or end hour of the following test(s) occurred during this non-operating hour: 'AAA'.	10/01/2021 01	10/01/2021 01	1
				10/01/2021 03	10/01/2021 03	1
	INFORM	<a href="#">HOUROP-56-A</a>	MODC 46 was reported for the O2 Dry monitor value which requires reporting MODC 46 for the NOx Concentration monitor value, but MODC 01 was reported.	10/12/2021 10	10/12/2021 10	1

#### Summary Data Errors

**Facility Name:** John Sevier

**Facility ID (ORISPL):** 3405

## Emissions Evaluation Report

April 20, 2022 12:49 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message
JCC1	CRIT1	<a href="#">HOURAGG-2-E</a>	The CurrentReportingPeriodTotal in the Summary Value record for SO2M could not be recalculated because of errors listed above.
		<a href="#">HOURAGG-3-E</a>	The CurrentReportingPeriodTotal in the Summary Value record for CO2M could not be recalculated because of errors listed above.
		<a href="#">HOURAGG-4-A</a>	The CurrentReportingPeriodTotal of 1103043.000 reported in the Summary Value record for HIT for the reporting period is inconsistent with the recalculated value of 1102445.
		<a href="#">HOURAGG-14-H</a>	The YearToDateTotal of 9737378.000 in the Summary Value record for HIT is inconsistent with the recalculated value of 9736780.000.