



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

November 18, 2022 05:02 PM

Facility Name: Barry

Facility Details

Facility ID (ORISPL): 3
State: AL
County: Mobile County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
7A	CYCLE	3 02/03/2020 13:18	CD1/CO2	CRIT1	CYCLE-13-A	You reported a test Begin Date, Hour, and Minute that is not the same as the Begin Date, Hour, and Minute of the first injection in the cycle time test.
				INFORM	CYCLE-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		4 02/03/2020 14:18	NX1/NOX	CRIT1	CYCLE-14-A	You reported a test End Date, Hour, and Minute that is not the same as the End Date, Hour, and Minute of the last injection in the cycle time test.
				INFORM	CYCLE-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.