



ECMPS Client Tool

Version 1.* 2022 Q1

Emissions Evaluation Report

March 25, 2022 01:25 PM

Facility Name: Mercer Generating Station

Facility Details

Facility ID (ORISPL): 2408
Monitoring Plan Location IDs: 1
State: NJ
County: Mercer County
Year/Quarter: 2016 Q4
Total Hours: 2208

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.
	HOURGEN-15-B	Warning: The three-level RATA conducted for each of the following monitoring systems have expired: System ID(s) 855. Except for a 720 operating-hour grace period extension, you will need monitor stack flow with another FLOW system or report substitute data until you perform another three-level RATA. Three-level RATAs expire after five years.

Hourly Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
1	CRIT1	HOURCV-7-B	The AdjustedHourlyValue reported in the DHV record for HI is inconsistent with the recalculated value.	11/16/2016 13	11/16/2016 13	1
		HOURCV-9-B	The AdjustedHourlyValue reported in the DHV record for SO2 is inconsistent with the recalculated value.	11/16/2016 13	11/16/2016 13	1
		HOURDHV-33-C	You reported an MODCCode of 40 in the DHV record for H2O, but the AdjustedHourlyValue is outside the range of the active default values in your monitoring plan.	11/16/2016 13	11/16/2016 13	1