



# ECMPS Client Tool

Version 1.\* 2022 Q2

## QA/Cert Test Evaluation Report

October 12, 2022 04:21 PM

Facility Name: Lincoln Combustion Turbine

### Facility Details

Facility ID (ORISPL): 7277  
State: NC  
County: Lincoln County

### Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
2	APPE	02NOX2016-1 02/04/2016 15:46	410/NOXE	CRIT1	<a href="#">APPE-38-A</a>	The Appendix E test contains fewer than three run records for Operating Level 1. A minimum of three runs are required at each operating level.
				INFORM	<a href="#">APPE-4-C</a>	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		02NOX2016-2 03/02/2016 09:00	400/NOXE	CRIT1	<a href="#">APPE-7-A</a>	One or more runs in this test have overlapping run times.
					<a href="#">APPE-8-A</a>	There are missing or non-sequential OperatingLevelForRun and RunNumbers in this test. Run numbers must begin with 1 and be consecutive within the entire test or within each operating level. The lowest OperatingLevelForRun must be equal to 1.
					<a href="#">APPE-43-A</a>	You have defined an inconsistent number of fuel flow records for this test. There must be the same combination of supporting fuel flow records for each run.
				INFORM	<a href="#">APPE-4-C</a>	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		02NOX2021-1 02/04/2021 16:06	410/NOXE	CRIT1	<a href="#">APPE-7-A</a>	One or more runs in this test have overlapping run times.
					<a href="#">APPE-41-A</a>	The AverageHourlyHeatInputRate reported for Operating Level 1 is inconsistent with the value recalculated from the run and fuel data for the operating level.
					<a href="#">APPE-44-A</a>	The HourlyHeatInputRate for Operating Level 1 Run Number 2 does not correspond to the hourly heat input rate recalculated from the start and end times and heat input derived from the Appendix E gas and oil records.
				INFORM	<a href="#">APPE-4-C</a>	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		02NOX2021-2 02/05/2021 15:26	400/NOXE	CRIT1	<a href="#">APPE-3-A</a>	You did not provide TestReasonCode, which is required for this test.
				INFORM	<a href="#">APPE-4-C</a>	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.