



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

October 7, 2022 09:18 PM

Facility Name: Barry

Facility Details

Facility ID (ORISPL): 3
Monitoring Plan Location IDs: 6A
State: AL
County: Mobile County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
6A	RATA	201905150756MA3 05/15/2019 12:37	MA3/NOX	NONCRIT	RATA-52-D	You reported a RATAFrequencyCode that is different from the value which was calculated from the runs of the RATA.
				INFORM	RATA-49-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
					RATA-132-A	You have reported more than 3 decimal places for ConfidenceCoefficient, MeanDifference, MeanRATAReferenceValue, and StandardDeviationDifference, which is not permitted by Part 75.
		202001070829MA3 01/07/2020 12:48	MA3/NOX	CRIT1	RATA-33-A	You did not provide RATAReferenceValue, which is required for Operating Level H Run Number 9.
				INFORM	RATA-35-B	The software could not evaluate the RATA calculations reported for Operating Level H, because of the errors listed above.
					RATA-49-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
				INFORM	RATA-132-A	You have reported more than 3 decimal places for ConfidenceCoefficient, MeanDifference, MeanRATAReferenceValue, and StandardDeviationDifference, which is not permitted by Part 75.
		202103021150MA3 03/02/2021 16:05	MA3/NOX	NONCRIT	RATA-36-A	The RATA summary record for Operating Level H contains an average gross unit load which is inconsistent with the average gross unit load recalculated from the run records used in the calculation of results.
				INFORM	RATA-49-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.