



ECMPS Client Tool

Version 1.* 2022 Q2

Emissions Evaluation Report

August 26, 2022 12:08 PM

Facility Name: Gerald Whelan Energy Center

Facility Details

Facility ID (ORISPL): 60
Monitoring Plan Location IDs: 1
State: NE
County: Adams County
Year/Quarter: 2021 Q4
Total Hours: 2208

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

Test Data Errors

Unit/Stack/ Pipe	Test Type	Test Date/Hour	Sys / Comp ID	Sys / Comp Type / Scale	Severity	Check Code	Result Message
1	DAYCAL	10/01/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/01/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/01/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/01/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		10/02/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/02/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/02/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/02/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		10/03/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/03/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/03/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/03/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.

Facility Name: Gerald Whelan Energy Center

Emissions Evaluation Report

August 26, 2022 12:08 PM

Facility ID (ORISPL): 60

Unit/Stack/ Pipe	Test Type	Test Date/Hour	Sys / Comp ID	Sys / Comp Type / Scale	Severity	Check Code	Result Message
1	DAYCAL	10/04/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/04/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/04/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/04/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		10/05/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/05/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/05/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/05/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		10/06/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/06/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/06/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/06/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		10/07/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/07/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/07/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/07/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		10/08/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/08/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/08/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/08/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		10/13/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/13/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/13/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/13/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.

Facility Name: Gerald Whelan Energy Center

Emissions Evaluation Report

August 26, 2022 12:08 PM

Facility ID (ORISPL): 60

Unit/Stack/ Pipe	Test Type	Test Date/Hour	Sys / Comp ID	Sys / Comp Type / Scale	Severity	Check Code	Result Message
1	DAYCAL	10/14/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/14/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/14/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/14/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		10/15/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/15/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/15/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/15/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		10/16/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/16/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/16/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/16/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		10/17/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/17/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/17/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/17/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		10/18/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/18/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/18/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/18/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		10/19/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/19/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/19/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/19/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.

Facility Name: Gerald Whelan Energy Center

Emissions Evaluation Report

August 26, 2022 12:08 PM

Facility ID (ORISPL): 60

Unit/Stack/ Pipe	Test Type	Test Date/Hour	Sys / Comp ID	Sys / Comp Type / Scale	Severity	Check Code	Result Message
1	DAYCAL	10/20/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/20/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/20/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/20/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		10/21/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/21/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/21/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/21/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		10/22/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/22/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/22/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/22/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		10/22/2021 08:34	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/22/2021 8:34:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/22/2021 8:34:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/22/2021 8:34:00 AM, but you did not report an UpscaleGasTypeCode.
		10/22/2021 09:08	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/22/2021 9:08:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/22/2021 9:08:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/22/2021 9:08:00 AM, but you did not report an UpscaleGasTypeCode.
		10/23/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/23/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/23/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/23/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.

Facility Name: Gerald Whelan Energy Center

Emissions Evaluation Report

August 26, 2022 12:08 PM

Facility ID (ORISPL): 60

Unit/Stack/ Pipe	Test Type	Test Date/Hour	Sys / Comp ID	Sys / Comp Type / Scale	Severity	Check Code	Result Message
1	DAYCAL	10/24/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/24/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/24/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/24/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		10/25/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/25/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/25/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/25/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		10/26/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/26/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/26/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/26/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		10/27/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/27/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/27/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/27/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		10/28/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/28/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/28/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/28/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		10/29/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/29/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/29/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/29/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.

Facility Name: Gerald Whelan Energy Center

Emissions Evaluation Report

August 26, 2022 12:08 PM

Facility ID (ORISPL): 60

Unit/Stack/ Pipe	Test Type	Test Date/Hour	Sys / Comp ID	Sys / Comp Type / Scale	Severity	Check Code	Result Message
1	DAYCAL	10/30/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/30/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/30/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/30/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		10/31/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 10/31/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 10/31/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 10/31/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		11/01/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/01/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/01/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/01/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		11/02/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/02/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/02/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/02/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		11/03/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/03/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/03/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/03/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		11/04/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/04/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/04/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/04/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.

Facility Name: Gerald Whelan Energy Center

Emissions Evaluation Report

Facility ID (ORISPL): 60

August 26, 2022 12:08 PM

Unit/Stack/ Pipe	Test Type	Test Date/Hour	Sys / Comp ID	Sys / Comp Type / Scale	Severity	Check Code	Result Message
1	DAYCAL	11/04/2021 10:07	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/04/2021 10:07:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/04/2021 10:07:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/04/2021 10:07:00 AM, but you did not report an UpscaleGasTypeCode.
		11/05/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/05/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/05/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/05/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		11/06/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/06/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/06/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/06/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		11/07/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/07/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/07/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/07/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		11/08/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/08/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/08/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/08/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		11/09/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/09/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/09/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/09/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.

Facility Name: Gerald Whelan Energy Center

Emissions Evaluation Report

Facility ID (ORISPL): 60

August 26, 2022 12:08 PM

Unit/Stack/ Pipe	Test Type	Test Date/Hour	Sys / Comp ID	Sys / Comp Type / Scale	Severity	Check Code	Result Message
1	DAYCAL	11/10/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/10/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/10/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/10/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		11/11/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/11/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/11/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/11/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		11/12/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/12/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/12/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/12/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		11/13/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/13/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/13/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/13/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		11/14/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/14/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/14/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/14/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		11/15/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/15/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/15/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/15/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.

Facility Name: Gerald Whelan Energy Center

Emissions Evaluation Report

August 26, 2022 12:08 PM

Facility ID (ORISPL): 60

Unit/Stack/ Pipe	Test Type	Test Date/Hour	Sys / Comp ID	Sys / Comp Type / Scale	Severity	Check Code	Result Message
1	DAYCAL	11/16/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/16/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/16/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/16/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		11/17/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/17/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/17/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/17/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		11/18/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/18/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/18/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/18/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		11/19/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/19/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/19/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/19/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		11/20/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/20/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/20/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/20/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		11/21/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/21/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/21/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/21/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.

Facility Name: Gerald Whelan Energy Center

Emissions Evaluation Report

August 26, 2022 12:08 PM

Facility ID (ORISPL): 60

Unit/Stack/ Pipe	Test Type	Test Date/Hour	Sys / Comp ID	Sys / Comp Type / Scale	Severity	Check Code	Result Message
1	DAYCAL	11/22/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/22/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/22/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/22/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		11/23/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/23/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/23/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/23/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		11/24/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/24/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/24/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/24/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		11/25/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/25/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/25/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/25/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		11/26/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/26/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/26/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/26/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		11/27/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/27/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/27/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/27/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.

Facility Name: Gerald Whelan Energy Center

Emissions Evaluation Report

August 26, 2022 12:08 PM

Facility ID (ORISPL): 60

Unit/Stack/ Pipe	Test Type	Test Date/Hour	Sys / Comp ID	Sys / Comp Type / Scale	Severity	Check Code	Result Message
1	DAYCAL	11/28/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/28/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/28/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/28/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		11/29/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/29/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/29/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/29/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		11/30/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/30/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/30/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/30/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		11/30/2021 07:12	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/30/2021 7:12:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/30/2021 7:12:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/30/2021 7:12:00 AM, but you did not report an UpscaleGasTypeCode.
		11/30/2021 10:37	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 11/30/2021 10:37:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 11/30/2021 10:37:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 11/30/2021 10:37:00 AM, but you did not report an UpscaleGasTypeCode.
		12/01/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/01/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/01/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/01/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.

Facility Name: Gerald Whelan Energy Center

Emissions Evaluation Report

Facility ID (ORISPL): 60

August 26, 2022 12:08 PM

Unit/Stack/ Pipe	Test Type	Test Date/Hour	Sys / Comp ID	Sys / Comp Type / Scale	Severity	Check Code	Result Message
1	DAYCAL	12/02/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/02/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/02/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/02/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		12/03/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/03/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/03/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/03/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		12/04/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/04/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/04/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/04/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		12/05/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/05/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/05/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/05/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		12/06/2021 10:05	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/06/2021 10:05:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/06/2021 10:05:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/06/2021 10:05:00 AM, but you did not report an UpscaleGasTypeCode.
		12/07/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/07/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/07/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/07/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.

Facility Name: Gerald Whelan Energy Center

Emissions Evaluation Report

August 26, 2022 12:08 PM

Facility ID (ORISPL): 60

Unit/Stack/ Pipe	Test Type	Test Date/Hour	Sys / Comp ID	Sys / Comp Type / Scale	Severity	Check Code	Result Message
1	DAYCAL	12/08/2021 09:09	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/08/2021 9:09:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/08/2021 9:09:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/08/2021 9:09:00 AM, but you did not report an UpscaleGasTypeCode.
		12/09/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/09/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/09/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/09/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		12/10/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/10/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/10/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/10/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		12/11/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/11/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/11/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/11/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		12/12/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/12/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/12/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/12/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		12/13/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/13/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/13/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/13/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.

Facility Name: Gerald Whelan Energy Center

Emissions Evaluation Report

Facility ID (ORISPL): 60

August 26, 2022 12:08 PM

Unit/Stack/ Pipe	Test Type	Test Date/Hour	Sys / Comp ID	Sys / Comp Type / Scale	Severity	Check Code	Result Message
1	DAYCAL	12/14/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/14/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/14/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/14/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		12/15/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/15/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/15/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/15/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		12/16/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/16/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/16/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/16/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		12/17/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/17/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/17/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/17/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		12/18/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/18/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/18/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/18/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		12/19/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/19/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/19/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/19/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.

Facility Name: Gerald Whelan Energy Center

Emissions Evaluation Report

Facility ID (ORISPL): 60

August 26, 2022 12:08 PM

Unit/Stack/ Pipe	Test Type	Test Date/Hour	Sys / Comp ID	Sys / Comp Type / Scale	Severity	Check Code	Result Message
1	DAYCAL	12/20/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/20/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/20/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/20/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		12/21/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/21/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/21/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/21/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		12/22/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/22/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/22/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/22/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		12/23/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/23/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/23/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/23/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		12/23/2021 08:32	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/23/2021 8:32:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/23/2021 8:32:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/23/2021 8:32:00 AM, but you did not report an UpscaleGasTypeCode.
		12/24/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/24/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/24/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/24/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.

Facility Name: Gerald Whelan Energy Center

Emissions Evaluation Report

August 26, 2022 12:08 PM

Facility ID (ORISPL): 60

Unit/Stack/ Pipe	Test Type	Test Date/Hour	Sys / Comp ID	Sys / Comp Type / Scale	Severity	Check Code	Result Message
1	DAYCAL	12/25/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/25/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/25/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/25/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		12/26/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/26/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/26/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/26/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		12/27/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/27/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/27/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/27/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		12/28/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/28/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/28/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/28/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		12/29/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/29/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/29/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/29/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
		12/30/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/30/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/30/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/30/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.

Facility Name: Gerald Whelan Energy Center

Emissions Evaluation Report

Facility ID (ORISPL): 60

August 26, 2022 12:08 PM

Unit/Stack/ Pipe	Test Type	Test Date/Hour	Sys / Comp ID	Sys / Comp Type / Scale	Severity	Check Code	Result Message
1	DAYCAL	12/31/2021 05:33	014	HCL/H	NONCRIT	DAYCAL-27-C	You reported a CylinderIdentifier for Location 1, Component 014 and Type HCL at 12/31/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-28-E	You reported a VendorIdentifier for Location 1, Component 014 and Type HCL at 12/31/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.
						DAYCAL-29-E	You reported a ExpirationDate for Location 1, Component 014 and Type HCL at 12/31/2021 5:33:00 AM, but you did not report an UpscaleGasTypeCode.

Hourly Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
1	INFORM	HOURCV-39-G	Warning: The AdjustedHourlyValue reported in the DHV record for HI is in excess of the maximum value listed in the monitoring plan. Sources are required to periodically (at least once annually) evaluate the appropriateness of these maximum values in the monitoring plan and make proper adjustments when necessary. Adjustments may include the need to update Span, Default, and/or Unit Capacity values. You should investigate the cause of these exceedances and determine whether adjustments to your monitoring systems or monitoring plan are necessary.	10/14/2021 14	10/14/2021 19	6
				10/16/2021 18	10/16/2021 20	3
				10/17/2021 08	10/17/2021 12	5
				10/21/2021 15	10/21/2021 20	6
				10/21/2021 22	10/22/2021 00	3
				10/22/2021 02	10/22/2021 18	17
				10/25/2021 09	10/25/2021 18	10
				10/31/2021 23	11/01/2021 00	2
				11/01/2021 02	11/01/2021 20	19
				11/01/2021 22	11/02/2021 00	3
				11/02/2021 02	11/02/2021 20	19
				11/02/2021 22	11/03/2021 07	10
				11/03/2021 16	11/03/2021 20	5
				11/03/2021 22	11/04/2021 00	3
				11/04/2021 02	11/04/2021 08	7
				11/04/2021 10	11/04/2021 14	5
				11/06/2021 13	11/06/2021 13	1
				11/09/2021 08	11/09/2021 08	1
				11/09/2021 12	11/09/2021 16	5
				11/12/2021 23	11/12/2021 23	1

Facility Name: Gerald Whelan Energy Center

Emissions Evaluation Report

Facility ID (ORISPL): 60

August 26, 2022 12:08 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
1	INFORM	HOURCV-39-G	Warning: The AdjustedHourlyValue reported in the DHV record for HI is in excess of the maximum value listed in the monitoring plan. Sources are required to periodically (at least once annually) evaluate the appropriateness of these maximum values in the monitoring plan and make proper adjustments when necessary. Adjustments may include the need to update Span, Default, and/or Unit Capacity values. You should investigate the cause of these exceedances and determine whether adjustments to your monitoring systems or monitoring plan are necessary.	11/13/2021 05	11/13/2021 05	1
				11/13/2021 10	11/13/2021 10	1
				11/14/2021 14	11/14/2021 15	2
				11/15/2021 14	11/15/2021 16	3
				11/20/2021 15	11/20/2021 15	1
				11/22/2021 14	11/22/2021 16	3
				11/22/2021 18	11/22/2021 18	1
				11/25/2021 14	11/25/2021 14	1
				11/28/2021 04	11/28/2021 12	9
				11/28/2021 14	11/28/2021 16	3
				11/29/2021 14	11/29/2021 16	3
				11/30/2021 01	11/30/2021 12	12
				12/02/2021 13	12/02/2021 15	3
				12/04/2021 09	12/04/2021 14	6
				12/08/2021 02	12/08/2021 03	2
				12/13/2021 08	12/13/2021 08	1
				12/13/2021 10	12/13/2021 12	3
				12/14/2021 10	12/14/2021 11	2
				12/18/2021 14	12/19/2021 02	13
				12/20/2021 20	12/20/2021 20	1
				12/20/2021 22	12/21/2021 00	3
				12/21/2021 02	12/21/2021 03	2
				12/21/2021 22	12/21/2021 23	2
				12/22/2021 02	12/22/2021 02	1
				12/22/2021 10	12/22/2021 11	2
				12/22/2021 14	12/22/2021 16	3
				12/23/2021 12	12/23/2021 13	2
				12/25/2021 07	12/25/2021 22	16

Facility Name: Gerald Whelan Energy Center

Emissions Evaluation Report

Facility ID (ORISPL): 60

August 26, 2022 12:08 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
1	INFORM	HOURCV-39-G	Warning: The AdjustedHourlyValue reported in the DHV record for HI is in excess of the maximum value listed in the monitoring plan. Sources are required to periodically (at least once annually) evaluate the appropriateness of these maximum values in the monitoring plan and make proper adjustments when necessary. Adjustments may include the need to update Span, Default, and/or Unit Capacity values. You should investigate the cause of these exceedances and determine whether adjustments to your monitoring systems or monitoring plan are necessary.	12/27/2021 13	12/27/2021 16	4
				12/29/2021 02	12/29/2021 03	2
				12/29/2021 05	12/29/2021 20	16
				12/29/2021 22	12/30/2021 00	3
				12/30/2021 02	12/30/2021 07	6
				12/30/2021 11	12/30/2021 11	1