



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

October 7, 2022 09:21 PM

Facility Name: Barry

Facility Details

Facility ID (ORISPL): 3
Monitoring Plan Location IDs: 7A
State: AL
County: Mobile County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
7A	RATA	202002110910MC3 02/11/2020 13:50	MC3/NOX	CRIT1	PGVP-6-B	You incorrectly reported a Protocol Gas Record for Cylinder Identifier CC456156. You should only report a Protocol Gas record for a RATA performed using instrumental reference methods 3A, 6C, or 7E.
						You incorrectly reported a Protocol Gas Record for Cylinder Identifier CC708012. You should only report a Protocol Gas record for a RATA performed using instrumental reference methods 3A, 6C, or 7E.
						You incorrectly reported a Protocol Gas Record for Cylinder Identifier EB0111514. You should only report a Protocol Gas record for a RATA performed using instrumental reference methods 3A, 6C, or 7E.
						You incorrectly reported a Protocol Gas Record for Cylinder Identifier XC007994B. You should only report a Protocol Gas record for a RATA performed using instrumental reference methods 3A, 6C, or 7E.
						You incorrectly reported a Protocol Gas Record for Gas Level LOW Gas Type ZERO. You should only report a Protocol Gas record for a RATA performed using instrumental reference methods 3A, 6C, or 7E.
					RATA-41-A	You did not report any operating level data for this test.
				INFORM	RATA-49-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		202103090816MC3 03/09/2021 12:28	MC3/NOX	INFORM	RATA-49-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.