



ECMPS Client Tool

Version 1.* 2022 Q1

Emissions Evaluation Report

March 4, 2022 02:26 PM

Facility Name: Bucksport Generation LLC

Facility Details

Facility ID (ORISPL): 50243
Monitoring Plan Location IDs: GEN4
State: ME
County: Hancock County
Year/Quarter: 2021 Q3
Total Hours: 2208

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

Hourly Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
GEN4	INFORM	HOURCV-39-G	Warning: The AdjustedHourlyValue reported in the DHV record for NOXR is in excess of the maximum value listed in the monitoring plan. Sources are required to periodically (at least once annually) evaluate the appropriateness of these maximum values in the monitoring plan and make proper adjustments when necessary. Adjustments may include the need to update Span, Default, and/or Unit Capacity values. You should investigate the cause of these exceedances and determine whether adjustments to your monitoring systems or monitoring plan are necessary.	07/06/2021 16	07/06/2021 16	1
				07/07/2021 15	07/07/2021 15	1
				07/17/2021 15	07/17/2021 15	1
				08/24/2021 16	08/24/2021 16	1
				08/25/2021 15	08/25/2021 15	1
				08/26/2021 15	08/26/2021 15	1
				09/23/2021 08	09/23/2021 09	2

Daily Emissions Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date	End Date	Consecutive Days
GEN4	CRIT1	DAILY-1-D	You did not report a Daily Emissions record for CO2M for the day.	07/06/2021 00	07/06/2021 00	1
		DAILY-2-A	The TotalDailyEmissions reported in the Daily Emissions record for CO2M is inconsistent with the recalculated value.	07/07/2021 00	07/07/2021 00	1

Facility Name: Bucksport Generation LLC

Emissions Evaluation Report

Facility ID (ORISPL): 50243

March 4, 2022 02:26 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date	End Date	Consecutive Days
GEN4	CRIT1	DAILY-3-A	The AdjustedDailyEmissions reported in the Daily Emissions record for CO2M is invalid. The value must be greater than or equal to 0.	07/17/2021 00	07/17/2021 00	1
		DAILY-4-A	The SorbentRelatedMassEmissions reported in the Daily Emissions record for CO2M is invalid. The value must be greater than or equal to 0.	08/11/2021 00	08/11/2021 00	1
		DAILY-5-A	You reported AdjustedDailyEmissions in the Daily Emissions record for CO2M, but you did not report a G-2 or G-3 formula in your monitoring plan.	07/17/2021 00	07/17/2021 00	1
		DAILY-6-A	You reported SorbentRelatedMassEmissions in the Daily Emissions record for CO2M, but you did not report G-5 or G-6 and G-8 formula(s) in your monitoring plan.	08/11/2021 00	08/11/2021 00	1
		DAILY-7-A	The UnadjustedDailyEmissions reported in the Daily Emissions record for CO2M is invalid. The value must be greater than or equal to 0.	08/17/2021 00	08/17/2021 00	1
		DAILY-8-A	You did not report an active Unit Fuel record for FuelCode PNG in your monitoring plan.	08/17/2021 00	08/17/2021 00	1
		DAILY-9-A	The DailyFuelFeed reported in the Daily Fuel record for Fuel Code NNG is missing or invalid. The value must be greater than 0.	08/18/2021 00	08/18/2021 00	1
		DAILY-10-A	The CarbonContentUsed in the Daily Fuel record for Fuel Code NNG is invalid. The value must be greater than 0 and less than or equal to 100.	08/18/2021 00	08/18/2021 00	1
		DAILY-11-A	The FuelCarbonBurned reported in the Daily Fuel record for Fuel Code NNG is missing or invalid. The value must be greater than 0.	08/18/2021 00	08/18/2021 00	1
		DAILY-13-B	The TotalCarbonBurned reported in the Daily Emissions record for CO2M is invalid. The value must be greater than or equal to 0.	08/24/2021 00	08/24/2021 00	1
	INFORM	DAILY-2-C	The TotalDailyEmissions in the Daily Emissions record for CO2M could not be recalculated due to other errors listed in this report.	07/17/2021 00	07/17/2021 00	1
				08/11/2021 00	08/11/2021 00	1

Summary Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message
GEN4	CRIT1	HOURAGG-3-E	The CurrentReportingPeriodTotal in the Summary Value record for CO2M could not be recalculated because of errors listed above.