



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

October 14, 2022 06:00 PM

Facility Name: Bethpage Energy Center

Facility Details

Facility ID (ORISPL): 50292
State: NY
County: Nassau County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
GT3	7DAY	21Q2-NOXH-7DAY 05/09/2021 17:21	310/NOX	CRIT1	SEVNDAY-20-A	You reported a Test End Date, Hour, and Minute that is not the same as the Injection Date, Hour, and Minute of the last injection in the 7 day calibration test.
					SEVNDAY-21-A	The test contains fewer than seven calibration injection records.
		21Q2-NOXL-7DAY 05/09/2021 17:22	310/NOX	INFORM	SEVNDAY-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
					SEVNDAY-20-A	You reported a Test End Date, Hour, and Minute that is not the same as the Injection Date, Hour, and Minute of the last injection in the 7 day calibration test.
		21Q2-O2-7DAY 05/09/2021 17:21	320/O2	CRIT1	SEVNDAY-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
					SEVNDAY-22-A	You have reported more than one value as the UpscaleGasLevelCode in the calibration injection records.
		7DAY-Q12018-105-1 02/14/2018 18:28	105/O2	CRIT1	SEVNDAY-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
					SEVNDAY-19-A	You reported a test Begin Date, Hour, and Minute that is not the same as the Injection Date, Hour, and Minute of the first injection in the 7-day calibration test.
				INFORM	SEVNDAY-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.