



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

November 19, 2022 04:28 PM

Facility Name: Lincoln Combustion Turbine

Facility Details

Facility ID (ORISPL): 7277
Monitoring Plan Location IDs: 1
State: NC
County: Lincoln County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
1	FFACCTT	U01G-030719 03/07/2019 08:00	012/H2O	CRIT1	FFACCTT-1-B	The component type in the monitoring plan is H2O. This type of component does not require a transmitter transducer test. Only component types 'OFFM' or 'GFFM' may perform this type of test.
					TEST-22-B	A Monitoring Plan associated with this test has not been evaluated. You must evaluate all active and future Monitoring Plans containing the location in this test in order to complete the evaluation of this test.
				INFORM	FFACCTT-4-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		U01G-051321 05/13/2021 09:00	012/H2O	CRIT1	FFACCTT-1-B	The component type in the monitoring plan is H2O. This type of component does not require a transmitter transducer test. Only component types 'OFFM' or 'GFFM' may perform this type of test.
					TEST-22-B	A Monitoring Plan associated with this test has not been evaluated. You must evaluate all active and future Monitoring Plans containing the location in this test in order to complete the evaluation of this test.
				INFORM	FFACCTT-4-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.