



ECMPS Client Tool

Version 1.* 2022 Q1

Emissions Evaluation Report

March 15, 2022 05:38 PM

Facility Name: Trimble County

Facility Details

Facility ID (ORISPL): 6071
Monitoring Plan Location IDs: MS-2A, MS-2B, 2
State: KY
County: Trimble County
Year/Quarter: 2021 Q4
Total Hours: 2208

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

Sorbent Trap Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message
MS-2B	INFORM	MATSTRN-17-A	For sampling train 26B/2BV from 12/20-09 through 12/27-10, at least 20 percent of the gas flow meter hours reported a Begin-End Flag of "N".