



ECMPS Client Tool

Version 1.* 2022 Q2

Emissions Evaluation Report

June 30, 2022 01:37 PM

Facility Name: Gans Generating Facility

Facility Details

Facility ID (ORISPL): 55377
Monitoring Plan Location IDs: 8
State: PA
County: Fayette County
Year/Quarter: 2020 Q4
Total Hours: 2208

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

Test Data Errors

Unit/Stack/ Pipe	Test Type	Test Date/Hour	Sys / Comp ID	Sys / Comp Type / Scale	Severity	Check Code	Result Message
8	DAYCAL	10/06/2020 06:11	011	NOX/H	CRIT1	DAYCAL-3-A	You did not provide OnlineOfflineIndicator, which is required for Location 8, Component 011 and Type NOX at 10/06/2020 6:11:00 AM.
			021	O2/H	INFORM	DAYCAL-2-A	The TestResultCode indicates that the daily calibration test for Location 8, Component 021 and Type O2 at 10/06/2020 6:11:00 AM was aborted. If the test was aborted for a reason not related to monitor performance, you should not report the test.

QA Status Errors

Unit/Stack/ Pipe	Category Description	Severity	Check Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
8	NOX Daily Calibration Status Evaluation	CRIT1	OOC-Prior Online Test Has Critical Errors	The prior online daily calibration test for Component ID 011, Span Scale H completed on 10-06-2020 at 06:11 has critical errors.	10/07/2020 09	10/07/2020 21	13
			OOC-Test Has Critical Errors	The prior daily calibration test for Component ID 011, Span Scale H completed on 10-06-2020 at 06:11 has critical errors.	10/06/2020 06	10/06/2020 19	14
	O2 Dry Daily Calibration Status Evaluation	CRIT1	OOC-Prior Online Test Aborted	The prior online daily calibration test for Component ID 021, Span Scale H completed on 10-06-2020 at 06:11 was aborted.	10/07/2020 09	10/07/2020 21	13

Facility Name: Gans Generating Facility

Emissions Evaluation Report

Facility ID (ORISPL): 55377

June 30, 2022 01:37 PM

Unit/Stack/ Pipe	Category Description	Severity	Check Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
8	O2 Dry Daily Calibration Status Evaluation	CRIT1	OOC-Prior Online Test Failed	The prior online daily calibration test for Component ID 021, Span Scale H completed on 12-12-2020 at 18:06 failed.	12/13/2020 16	12/13/2020 16	1
			OOC-Test Aborted	The prior daily calibration test for Component ID 021, Span Scale H completed on 10-06-2020 at 06:11 was aborted.	10/06/2020 06	10/06/2020 19	14