



ECMPS Client Tool

Version 1.* 2022 Q2

Emissions Evaluation Report

September 23, 2022 04:18 PM

Facility Name: Danskammer Generating Station

Facility Details

Facility ID (ORISPL): 2480
Monitoring Plan Location IDs: 3
State: NY
County: Orange County
Year/Quarter: 2021 Q3
Total Hours: 2208

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.
	HOURGEN-15-B	Warning: The three-level RATA conducted for each of the following monitoring systems have expired: System ID(s) 330. Except for a 720 operating-hour grace period extension, you will need monitor stack flow with another FLOW system or report substitute data until you perform another three-level RATA. Three-level RATAs expire after five years.