



ECMPS Client Tool

Version 1.* 2022 Q1

Emissions Evaluation Report

March 4, 2022 04:15 PM

Facility Name: Muscatine

Facility Details

Facility ID (ORISPL): 1167
Monitoring Plan Location IDs: 9
State: IA
County: Muscatine County
Year/Quarter: 2021 Q3
Total Hours: 2208

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

Test Data Errors

Unit/Stack/ Pipe	Test Type	Test Date/Hour	Sys / Comp ID	Sys / Comp Type / Scale	Severity	Check Code	Result Message
9	DAYCAL	07/01/2021 05	201	SO2/L	FATAL	EMTEST-3-A	You did not provide Minute, which is required for Location 9, Component 201 and Type SO2 at 07/01/2021 5:00:00 AM.
					CRIT1	EMTEST-4-A	You have reported both a MonitoringSystemID and a ComponentID for Location 9, Component 201 and Type SO2 at 07/01/2021 5:00:00 AM. This is invalid.
	INTCHK	07/01/2021 05:30	402	FLOW/H	CRIT1	EMTEST-5-A	You reported SpanScaleCode for this test, which is not appropriate for this test type.
						EMTEST-6-B	You reported the value PASSAPS, which is not in the list of valid values for this test type, in the field TestResultCode for this test.

QA Status Errors

Unit/Stack/ Pipe	Category Description	Severity	Check Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
9	Daily Interference Check Status Evaluation	CRIT1	OOC-Test Has Critical Errors	The prior daily interference check for Component ID 402 completed on 07/01/2021 has critical errors.	07/01/2021 05	07/02/2021 04	24
	SO2 Daily Calibration Status Evaluation	CRIT1	OOC-Test Has Critical Errors	The prior daily calibration test for Component ID 201, Span Scale L completed on 07-01-2021 at hour 05 has critical errors.	07/01/2021 05	07/01/2021 16	12
					07/01/2021 18	07/02/2021 04	11

Hourly Data Errors

Facility Name: Muscatine

Facility ID (ORISPL): 1167

Emissions Evaluation Report

March 4, 2022 04:15 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
9	INFORM	HOURCV-37-C	Warning: The UnadjustedHourlyValue reported in the DHV record for NOXR is in excess of the maximum value listed in the monitoring plan. Sources are required to periodically (at least once annually) evaluate the appropriateness of these maximum values in the monitoring plan and make proper adjustments when necessary. Adjustments may include the need to update Span and/or Default values. You should investigate the cause of these exceedances and determine whether adjustments to your monitoring systems or monitoring plan are necessary.	07/24/2021 14	07/24/2021 14	1
				07/28/2021 20	07/28/2021 20	1
		HOURMHV-16-D	Warning: The UnadjustedHourlyValue reported in the MHV record for NOXC is in excess of the maximum value listed in the monitoring plan. Sources are required to periodically (at least once annually) evaluate the appropriateness of these maximum values in the monitoring plan and make proper adjustments when necessary. Adjustments may include the need to update Span and/or Default values. You should investigate the cause of these exceedances and determine whether adjustments to your monitoring systems or monitoring plan are necessary.	07/24/2021 14	07/24/2021 14	1
				07/28/2021 20	07/28/2021 20	1
		MATSDHV-9-B	You reported MODC 37 for HGRH, but did not report both a heat-input based MATS parameter, and a Startup/Shutdown Flag.	07/28/2021 17	07/28/2021 17	1

Audit Results

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message
9	INFORM	EMAUDIT-1-B	You have reported hourly data using Like Kind component 'LK2' for 603 hour(s) this year. Please be aware that the use of like kind monitors is limited to less than 720 hours on an annual basis.