



ECMPS Client Tool

Version 1.* 2022 Q1

Emissions Evaluation Report

May 13, 2022 02:34 PM

Facility Name: J H Campbell

Facility Details

Facility ID (ORISPL): 1710
Monitoring Plan Location IDs: 3
State: MI
County: Ottawa County
Year/Quarter: 2021 Q3
Total Hours: 2208

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
CRIT1	HOURGEN-8-B	The Monitoring Plan associated with this quarterly emissions file has not been evaluated. You must evaluate the Monitoring Plan for this monitoring configuration in order to complete the evaluation of this emissions file.
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

Hourly Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
3	CRIT1	MATSCHV-15-C	You reported a FormulaIdentifier in the MATS Derived Hourly Value record for HGRH, but you did not report a value for all the essential parameters needed to perform the calculation.	07/02/2021 16	07/02/2021 16	1
		MATSMHV-10-A	You reported MonitoringSystemID 360 ComponentID H04 in the MATS MHV record for HGC, but there is no MonitorSystemComponent record for this system and component in your monitoring plan that was active during the hour.	07/02/2021 16	07/02/2021 16	1
		MATSMHV-11-B	You have no active High Range SpanScaleCode at the current location for the hour.	09/30/2021 23	09/30/2021 23	1
		MATSMHV-12-C	The UNADJUSTED_HRLY_VALUE value in the Location 3, Parameter HGC records is not reported in scientific notation rounded to three significant figures, with one digit to the left of the decimal point.	07/02/2021 16	07/02/2021 16	1
		MATSMHV-17-A	You did not report one (and only one) valid Analyzer Range record in your monitoring plan for ComponentID H04 for this hour. The QA Status of the linearity and/or daily calibration tests for this component will not be evaluated.	07/02/2021 16	07/02/2021 16	1
		MATSMHV-19-C	You did not report a prior Three-Point Hg System Integrity Check or certification event for H04.	07/02/2021 16	07/02/2021 16	1
		MATSMHV-20-C	You did not report a prior Mercury Linearity or certification event for H04.	07/02/2021 16	07/02/2021 16	1

Facility Name: J H Campbell

Facility ID (ORISPL): 1710

Emissions Evaluation Report

May 13, 2022 02:34 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
3	INFORM	HOURCV-37-C	Warning: The UnadjustedHourlyValue reported in the DHV record for NOXR is in excess of the maximum value listed in the monitoring plan. Sources are required to periodically (at least once annually) evaluate the appropriateness of these maximum values in the monitoring plan and make proper adjustments when necessary. Adjustments may include the need to update Span and/or Default values. You should investigate the cause of these exceedances and determine whether adjustments to your monitoring systems or monitoring plan are necessary.	07/03/2021 18	07/03/2021 19	2
				09/20/2021 13	09/20/2021 15	3