



ECMPS Client Tool

Version 1.* 2022 Q1

Emissions Evaluation Report

March 24, 2022 04:31 PM

Facility Name: Ray Olinger

Facility Details

Facility ID (ORISPL): 3576
Monitoring Plan Location IDs: BW2
State: TX
County: Collin County
Year/Quarter: 2021 Q4
Total Hours: 2208

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

Hourly Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
BW2	CRIT1	HOURDHV-26-A	You reported FormulaID 220 in the DHV record for NOX, but you did not report a FormulaCode for this formula in your monitoring plan.	11/14/2021 13	11/15/2021 11	23
				11/16/2021 14	11/16/2021 18	5
				11/17/2021 07	11/17/2021 14	8
				11/18/2021 10	11/18/2021 13	4
				11/19/2021 03	11/19/2021 10	8
				11/20/2021 08	11/20/2021 11	4
				11/21/2021 00	11/21/2021 08	9
				11/22/2021 08	11/22/2021 10	3
				11/23/2021 02	11/23/2021 12	11
				11/24/2021 04	11/24/2021 07	4
				11/25/2021 03	11/25/2021 13	11
				11/26/2021 10	11/26/2021 13	4
				11/27/2021 03	11/27/2021 12	10

Facility Name: Ray Olinger

Facility ID (ORISPL): 3576

Emissions Evaluation Report

March 24, 2022 04:31 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
BW2	CRIT1	HOORDHV-26-A	You reported FormulaID 220 in the DHV record for NOX, but you did not report a FormulaCode for this formula in your monitoring plan.	11/28/2021 14	11/28/2021 18	5
				11/29/2021 02	11/29/2021 10	9
				11/30/2021 05	11/30/2021 10	6
				11/30/2021 22	12/01/2021 22	25
				12/04/2021 22	12/05/2021 11	14
				12/06/2021 08	12/06/2021 11	4
				12/07/2021 02	12/07/2021 10	9
				12/08/2021 04	12/08/2021 09	6
				12/08/2021 22	12/09/2021 04	7
				12/10/2021 02	12/10/2021 23	22
				12/11/2021 18	12/11/2021 21	4
				12/12/2021 07	12/12/2021 14	8
				12/13/2021 08	12/13/2021 09	2
				12/13/2021 21	12/14/2021 03	7
				12/14/2021 19	12/14/2021 21	3
				12/15/2021 11	12/15/2021 14	4
				12/15/2021 21	12/16/2021 22	26
				12/18/2021 06	12/18/2021 08	3
				12/19/2021 03	12/19/2021 11	9
				12/20/2021 08	12/20/2021 11	4
				12/20/2021 23	12/21/2021 09	11
				12/22/2021 07	12/22/2021 11	5
				12/22/2021 23	12/23/2021 08	10
				12/24/2021 05	12/24/2021 08	4
				12/24/2021 18	12/24/2021 23	6
				12/25/2021 17	12/25/2021 20	4
				12/26/2021 08	12/26/2021 15	8
				12/27/2021 05	12/27/2021 07	3

Facility Name: Ray Olinger

Facility ID (ORISPL): 3576

Emissions Evaluation Report

March 24, 2022 04:31 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
BW2	CRIT1	HOORDHV-26-A	You reported FormulaID 220 in the DHV record for NOX, but you did not report a FormulaCode for this formula in your monitoring plan.	12/28/2021 03	12/28/2021 12	10
				12/29/2021 10	12/29/2021 13	4
				12/30/2021 06	12/30/2021 13	8
				12/31/2021 08	12/31/2021 12	5
		HOORDHV-27-A	You reported FormulaID 120 in the DHV record for NOXR, but you did not report a FormulaCode for this formula in your monitoring plan.	11/14/2021 13	11/15/2021 11	23
				11/16/2021 14	11/16/2021 18	5
				11/17/2021 07	11/17/2021 14	8
				11/18/2021 10	11/18/2021 13	4
				11/19/2021 03	11/19/2021 10	8
				11/20/2021 08	11/20/2021 11	4
				11/21/2021 00	11/21/2021 08	9
				11/22/2021 08	11/22/2021 10	3
				11/23/2021 02	11/23/2021 12	11
				11/24/2021 04	11/24/2021 07	4
				11/25/2021 03	11/25/2021 13	11
				11/26/2021 10	11/26/2021 13	4
				11/27/2021 03	11/27/2021 12	10
				11/28/2021 14	11/28/2021 18	5
				11/29/2021 02	11/29/2021 10	9
				11/30/2021 05	11/30/2021 10	6
				11/30/2021 22	12/01/2021 22	25
				12/04/2021 22	12/05/2021 11	14
				12/06/2021 08	12/06/2021 11	4
				12/07/2021 02	12/07/2021 10	9
				12/08/2021 04	12/08/2021 09	6
				12/08/2021 22	12/09/2021 04	7
				12/10/2021 02	12/10/2021 23	22
				12/11/2021 18	12/11/2021 21	4

Facility Name: Ray Olinger

Facility ID (ORISPL): 3576

Emissions Evaluation Report

March 24, 2022 04:31 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
BW2	CRIT1	HOURDHV-27-A	You reported FormulaID 120 in the DHV record for NOXR, but you did not report a FormulaCode for this formula in your monitoring plan.	12/12/2021 07	12/12/2021 14	8
				12/13/2021 08	12/13/2021 09	2
				12/13/2021 21	12/14/2021 03	7
				12/14/2021 19	12/14/2021 21	3
				12/15/2021 11	12/15/2021 14	4
				12/15/2021 21	12/16/2021 22	26
				12/18/2021 06	12/18/2021 08	3
				12/19/2021 03	12/19/2021 11	9
				12/20/2021 08	12/20/2021 11	4
				12/20/2021 23	12/21/2021 09	11
				12/22/2021 07	12/22/2021 11	5
				12/22/2021 23	12/23/2021 08	10
				12/24/2021 05	12/24/2021 08	4
				12/24/2021 18	12/24/2021 23	6
				12/25/2021 17	12/25/2021 20	4
				12/26/2021 08	12/26/2021 15	8
				12/27/2021 05	12/27/2021 07	3
				12/28/2021 03	12/28/2021 12	10
				12/29/2021 10	12/29/2021 13	4
				12/30/2021 06	12/30/2021 13	8
				12/31/2021 08	12/31/2021 12	5
	NONCRIT	HOUROP-23-D	You reported a MHV or DHV record for CO2C, but this record is not required to calculate emissions.	11/14/2021 13	11/15/2021 11	23
				11/16/2021 14	11/16/2021 18	5
				11/17/2021 07	11/17/2021 14	8
				11/18/2021 10	11/18/2021 13	4
				11/19/2021 03	11/19/2021 10	8
				11/20/2021 08	11/20/2021 11	4
				11/21/2021 00	11/21/2021 08	9

Facility Name: Ray Olinger

Facility ID (ORISPL): 3576

Emissions Evaluation Report

March 24, 2022 04:31 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
BW2	NONCRIT	HOUROP-23-D	You reported a MHV or DHV record for CO2C, but this record is not required to calculate emissions.	11/22/2021 08	11/22/2021 10	3
				11/23/2021 02	11/23/2021 12	11
				11/24/2021 04	11/24/2021 07	4
				11/25/2021 03	11/25/2021 13	11
				11/26/2021 10	11/26/2021 13	4
				11/27/2021 03	11/27/2021 12	10
				11/28/2021 14	11/28/2021 18	5
				11/29/2021 02	11/29/2021 10	9
				11/30/2021 05	11/30/2021 10	6
				11/30/2021 22	12/01/2021 22	25
				12/04/2021 22	12/05/2021 11	14
				12/06/2021 08	12/06/2021 11	4
				12/07/2021 02	12/07/2021 10	9
				12/08/2021 04	12/08/2021 09	6
				12/08/2021 22	12/09/2021 04	7
				12/10/2021 02	12/10/2021 23	22
				12/11/2021 18	12/11/2021 21	4
				12/12/2021 07	12/12/2021 14	8
				12/13/2021 08	12/13/2021 09	2
				12/13/2021 21	12/14/2021 03	7
				12/14/2021 19	12/14/2021 21	3
				12/15/2021 11	12/15/2021 14	4
				12/15/2021 21	12/16/2021 22	26
				12/18/2021 06	12/18/2021 08	3
				12/19/2021 03	12/19/2021 11	9
				12/20/2021 08	12/20/2021 11	4
				12/20/2021 23	12/21/2021 09	11
				12/22/2021 07	12/22/2021 11	5

Facility Name: Ray Olinger

Facility ID (ORISPL): 3576

Emissions Evaluation Report

March 24, 2022 04:31 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
BW2	NONCRIT	HOUROP-23-D	You reported a MHV or DHV record for CO2C, but this record is not required to calculate emissions.	12/22/2021 23	12/23/2021 08	10
				12/24/2021 05	12/24/2021 08	4
				12/24/2021 18	12/24/2021 23	6
				12/25/2021 17	12/25/2021 20	4
				12/26/2021 08	12/26/2021 15	8
				12/27/2021 05	12/27/2021 07	3
				12/28/2021 03	12/28/2021 12	10
				12/29/2021 10	12/29/2021 13	4
				12/30/2021 06	12/30/2021 13	8
				12/31/2021 08	12/31/2021 12	5
INFORM		HOURCV-16-A	The AdjustedHourlyValue in the DHV record for NOX could not be recalculated due to errors listed above.	11/14/2021 13	11/15/2021 11	23
				11/16/2021 14	11/16/2021 18	5
				11/17/2021 07	11/17/2021 14	8
				11/18/2021 10	11/18/2021 13	4
				11/19/2021 03	11/19/2021 10	8
				11/20/2021 08	11/20/2021 11	4
				11/21/2021 00	11/21/2021 08	9
				11/22/2021 08	11/22/2021 10	3
				11/23/2021 02	11/23/2021 12	11
				11/24/2021 04	11/24/2021 07	4
				11/25/2021 03	11/25/2021 13	11
				11/26/2021 10	11/26/2021 13	4
				11/27/2021 03	11/27/2021 12	10
				11/28/2021 14	11/28/2021 18	5
				11/29/2021 02	11/29/2021 10	9
				11/30/2021 05	11/30/2021 10	6
				11/30/2021 22	12/01/2021 22	25
				12/04/2021 22	12/05/2021 11	14

Facility Name: Ray Olinger

Facility ID (ORISPL): 3576

Emissions Evaluation Report

March 24, 2022 04:31 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
BW2	INFORM	HOURCV-16-A	The AdjustedHourlyValue in the DHV record for NOX could not be recalculated due to errors listed above.	12/06/2021 08	12/06/2021 11	4
				12/07/2021 02	12/07/2021 10	9
				12/08/2021 04	12/08/2021 09	6
				12/08/2021 22	12/09/2021 04	7
				12/10/2021 02	12/10/2021 23	22
				12/11/2021 18	12/11/2021 21	4
				12/12/2021 07	12/12/2021 14	8
				12/13/2021 08	12/13/2021 09	2
				12/13/2021 21	12/14/2021 03	7
				12/14/2021 19	12/14/2021 21	3
				12/15/2021 11	12/15/2021 14	4
				12/15/2021 21	12/16/2021 22	26
				12/18/2021 06	12/18/2021 08	3
				12/19/2021 03	12/19/2021 11	9
				12/20/2021 08	12/20/2021 11	4
				12/20/2021 23	12/21/2021 09	11
				12/22/2021 07	12/22/2021 11	5
				12/22/2021 23	12/23/2021 08	10
				12/24/2021 05	12/24/2021 08	4
				12/24/2021 18	12/24/2021 23	6
				12/25/2021 17	12/25/2021 20	4
				12/26/2021 08	12/26/2021 15	8
				12/27/2021 05	12/27/2021 07	3
				12/28/2021 03	12/28/2021 12	10
				12/29/2021 10	12/29/2021 13	4
				12/30/2021 06	12/30/2021 13	8
				12/31/2021 08	12/31/2021 12	5
		HOURCV-41-A	The AdjustedHourlyValue in the DHV record for NOXR could not be recalculated due to errors listed above.	11/14/2021 13	11/15/2021 11	23

Facility Name: Ray Olinger

Facility ID (ORISPL): 3576

Emissions Evaluation Report

March 24, 2022 04:31 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
BW2	INFORM	HOURCV-41-A	The AdjustedHourlyValue in the DHV record for NOXR could not be recalculated due to errors listed above.	11/16/2021 14	11/16/2021 18	5
				11/17/2021 07	11/17/2021 14	8
				11/18/2021 10	11/18/2021 13	4
				11/19/2021 03	11/19/2021 10	8
				11/20/2021 08	11/20/2021 11	4
				11/21/2021 00	11/21/2021 08	9
				11/22/2021 08	11/22/2021 10	3
				11/23/2021 02	11/23/2021 12	11
				11/24/2021 04	11/24/2021 07	4
				11/25/2021 03	11/25/2021 13	11
				11/26/2021 10	11/26/2021 13	4
				11/27/2021 03	11/27/2021 12	10
				11/28/2021 14	11/28/2021 18	5
				11/29/2021 02	11/29/2021 10	9
				11/30/2021 05	11/30/2021 10	6
				11/30/2021 22	12/01/2021 22	25
				12/04/2021 22	12/05/2021 11	14
				12/06/2021 08	12/06/2021 11	4
				12/07/2021 02	12/07/2021 10	9
				12/08/2021 04	12/08/2021 09	6
				12/08/2021 22	12/09/2021 04	7
				12/10/2021 02	12/10/2021 23	22
				12/11/2021 18	12/11/2021 21	4
				12/12/2021 07	12/12/2021 14	8
				12/13/2021 08	12/13/2021 09	2
				12/13/2021 21	12/14/2021 03	7
				12/14/2021 19	12/14/2021 21	3
				12/15/2021 11	12/15/2021 14	4

Facility Name: Ray Olinger

Facility ID (ORISPL): 3576

Emissions Evaluation Report

March 24, 2022 04:31 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
BW2	INFORM	HOURCV-41-A	The AdjustedHourlyValue in the DHV record for NOXR could not be recalculated due to errors listed above.	12/15/2021 21	12/16/2021 22	26
				12/18/2021 06	12/18/2021 08	3
				12/19/2021 03	12/19/2021 11	9
				12/20/2021 08	12/20/2021 11	4
				12/20/2021 23	12/21/2021 09	11
				12/22/2021 07	12/22/2021 11	5
				12/22/2021 23	12/23/2021 08	10
				12/24/2021 05	12/24/2021 08	4
				12/24/2021 18	12/24/2021 23	6
				12/25/2021 17	12/25/2021 20	4
				12/26/2021 08	12/26/2021 15	8
				12/27/2021 05	12/27/2021 07	3
				12/28/2021 03	12/28/2021 12	10
				12/29/2021 10	12/29/2021 13	4
				12/30/2021 06	12/30/2021 13	8
				12/31/2021 08	12/31/2021 12	5
		HOURDHV-25-C	You reported FormulaID 121 in the DHV record for HI, but a formula with a FormulaCode F-20 is no longer appropriate in this record. For ECMPS, if you are calculating heat input from multiple fuels using Appendix D, you should report a formula with a FormulaCode of D-15A in the DHV record; otherwise, do not report a FormulaID.	11/14/2021 13	11/15/2021 11	23
				11/16/2021 14	11/16/2021 18	5
				11/17/2021 07	11/17/2021 14	8
				11/18/2021 10	11/18/2021 13	4
				11/19/2021 03	11/19/2021 10	8
				11/20/2021 08	11/20/2021 11	4
				11/21/2021 00	11/21/2021 08	9
				11/22/2021 08	11/22/2021 10	3
				11/23/2021 02	11/23/2021 12	11
				11/24/2021 04	11/24/2021 07	4
				11/25/2021 03	11/25/2021 13	11
				11/26/2021 10	11/26/2021 13	4

Facility Name: Ray Olinger

Facility ID (ORISPL): 3576

Emissions Evaluation Report

March 24, 2022 04:31 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
BW2	INFORM	HOORDHV-25-C	You reported FormulaID 121 in the DHV record for HI, but a formula with a FormulaCode F-20 is no longer appropriate in this record. For ECMPs, if you are calculating heat input from multiple fuels using Appendix D, you should report a formula with a FormulaCode of D-15A in the DHV record; otherwise, do not report a FormulaID.	11/27/2021 03	11/27/2021 12	10
				11/28/2021 14	11/28/2021 18	5
				11/29/2021 02	11/29/2021 10	9
				11/30/2021 05	11/30/2021 10	6
				11/30/2021 22	12/01/2021 22	25
				12/04/2021 22	12/05/2021 11	14
				12/06/2021 08	12/06/2021 11	4
				12/07/2021 02	12/07/2021 10	9
				12/08/2021 04	12/08/2021 09	6
				12/08/2021 22	12/09/2021 04	7
				12/10/2021 02	12/10/2021 23	22
				12/11/2021 18	12/11/2021 21	4
				12/12/2021 07	12/12/2021 14	8
				12/13/2021 08	12/13/2021 09	2
				12/13/2021 21	12/14/2021 03	7
				12/14/2021 19	12/14/2021 21	3
				12/15/2021 11	12/15/2021 14	4
				12/15/2021 21	12/16/2021 22	26
				12/18/2021 06	12/18/2021 08	3
				12/19/2021 03	12/19/2021 11	9
				12/20/2021 08	12/20/2021 11	4
				12/20/2021 23	12/21/2021 09	11
				12/22/2021 07	12/22/2021 11	5
				12/22/2021 23	12/23/2021 08	10
				12/24/2021 05	12/24/2021 08	4
				12/24/2021 18	12/24/2021 23	6
				12/25/2021 17	12/25/2021 20	4
				12/26/2021 08	12/26/2021 15	8

Facility Name: Ray Olinger

Facility ID (ORISPL): 3576

Emissions Evaluation Report

March 24, 2022 04:31 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
BW2	INFORM	HOURLDHV-25-C	You reported FormulaID 121 in the DHV record for HI, but a formula with a FormulaCode F-20 is no longer appropriate in this record. For ECMPS, if you are calculating heat input from multiple fuels using Appendix D, you should report a formula with a FormulaCode of D-15A in the DHV record; otherwise, do not report a FormulaID.	12/27/2021 05	12/27/2021 07	3
				12/28/2021 03	12/28/2021 12	10
				12/29/2021 10	12/29/2021 13	4
				12/30/2021 06	12/30/2021 13	8
				12/31/2021 08	12/31/2021 12	5
		HOURLDHV-29-B	You reported FormulaID 126 in the DHV record for CO2, but a formula with a FormulaCode G-4 is no longer appropriate in this record. For ECMPS, if you are calculating CO2 from multiple fuels using Appendix D, you should report a formula with a FormulaCode of G-4A in the DHV record; otherwise, do not report a FormulaID.	11/14/2021 13	11/15/2021 11	23
				11/16/2021 14	11/16/2021 18	5
				11/17/2021 07	11/17/2021 14	8
				11/18/2021 10	11/18/2021 13	4
				11/19/2021 03	11/19/2021 10	8
				11/20/2021 08	11/20/2021 11	4
				11/21/2021 00	11/21/2021 08	9
				11/22/2021 08	11/22/2021 10	3
				11/23/2021 02	11/23/2021 12	11
				11/24/2021 04	11/24/2021 07	4
				11/25/2021 03	11/25/2021 13	11
				11/26/2021 10	11/26/2021 13	4
				11/27/2021 03	11/27/2021 12	10
				11/28/2021 14	11/28/2021 18	5
				11/29/2021 02	11/29/2021 10	9
				11/30/2021 05	11/30/2021 10	6
				11/30/2021 22	12/01/2021 22	25
				12/04/2021 22	12/05/2021 11	14
				12/06/2021 08	12/06/2021 11	4
				12/07/2021 02	12/07/2021 10	9
				12/08/2021 04	12/08/2021 09	6
				12/08/2021 22	12/09/2021 04	7
				12/10/2021 02	12/10/2021 23	22

Facility Name: Ray Olinger

Facility ID (ORISPL): 3576

Emissions Evaluation Report

March 24, 2022 04:31 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
BW2	INFORM	HOORDHV-29-B	You reported FormulaID 126 in the DHV record for CO2, but a formula with a FormulaCode G-4 is no longer appropriate in this record. For ECMPS, if you are calculating CO2 from multiple fuels using Appendix D, you should report a formula with a FormulaCode of G-4A in the DHV record; otherwise, do not report a FormulaID.	12/11/2021 18	12/11/2021 21	4
				12/12/2021 07	12/12/2021 14	8
				12/13/2021 08	12/13/2021 09	2
				12/13/2021 21	12/14/2021 03	7
				12/14/2021 19	12/14/2021 21	3
				12/15/2021 11	12/15/2021 14	4
				12/15/2021 21	12/16/2021 22	26
				12/18/2021 06	12/18/2021 08	3
				12/19/2021 03	12/19/2021 11	9
				12/20/2021 08	12/20/2021 11	4
				12/20/2021 23	12/21/2021 09	11
				12/22/2021 07	12/22/2021 11	5
				12/22/2021 23	12/23/2021 08	10
				12/24/2021 05	12/24/2021 08	4
				12/24/2021 18	12/24/2021 23	6
				12/25/2021 17	12/25/2021 20	4
				12/26/2021 08	12/26/2021 15	8
				12/27/2021 05	12/27/2021 07	3
				12/28/2021 03	12/28/2021 12	10
				12/29/2021 10	12/29/2021 13	4
				12/30/2021 06	12/30/2021 13	8
				12/31/2021 08	12/31/2021 12	5
		HOORDHV-30-C	You reported FormulaID 123 in the DHV record for SO2, but a formula with a FormulaCode D-5 is not appropriate in this record. If you are calculating SO2 from multiple fuels using Appendix D, you should report a formula with a FormulaCode of D-12 in the DHV record; otherwise, do not report a FormulaID.	11/14/2021 13	11/15/2021 11	23
				11/16/2021 14	11/16/2021 18	5
				11/17/2021 07	11/17/2021 14	8
				11/18/2021 10	11/18/2021 13	4
				11/19/2021 03	11/19/2021 10	8
				11/20/2021 08	11/20/2021 11	4

Facility Name: Ray Olinger

Facility ID (ORISPL): 3576

Emissions Evaluation Report

March 24, 2022 04:31 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
BW2	INFORM	HOORDHV-30-C	You reported FormulaID 123 in the DHV record for SO2, but a formula with a FormulaCode D-5 is not appropriate in this record. If you are calculating SO2 from multiple fuels using Appendix D, you should report a formula with a FormulaCode of D-12 in the DHV record; otherwise, do not report a FormulaID.	11/21/2021 00	11/21/2021 08	9
				11/22/2021 08	11/22/2021 10	3
				11/23/2021 02	11/23/2021 12	11
				11/24/2021 04	11/24/2021 07	4
				11/25/2021 03	11/25/2021 13	11
				11/26/2021 10	11/26/2021 13	4
				11/27/2021 03	11/27/2021 12	10
				11/28/2021 14	11/28/2021 18	5
				11/29/2021 02	11/29/2021 10	9
				11/30/2021 05	11/30/2021 10	6
				11/30/2021 22	12/01/2021 22	25
				12/04/2021 22	12/05/2021 11	14
				12/06/2021 08	12/06/2021 11	4
				12/07/2021 02	12/07/2021 10	9
				12/08/2021 04	12/08/2021 09	6
				12/08/2021 22	12/09/2021 04	7
				12/10/2021 02	12/10/2021 23	22
				12/11/2021 18	12/11/2021 21	4
				12/12/2021 07	12/12/2021 14	8
				12/13/2021 08	12/13/2021 09	2
				12/13/2021 21	12/14/2021 03	7
				12/14/2021 19	12/14/2021 21	3
				12/15/2021 11	12/15/2021 14	4
				12/15/2021 21	12/16/2021 22	26
				12/18/2021 06	12/18/2021 08	3
				12/19/2021 03	12/19/2021 11	9
				12/20/2021 08	12/20/2021 11	4
				12/20/2021 23	12/21/2021 09	11

Facility Name: Ray Olinger

Facility ID (ORISPL): 3576

Emissions Evaluation Report

March 24, 2022 04:31 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
BW2	INFORM	HOURDHV-30-C	You reported FormulaID 123 in the DHV record for SO2, but a formula with a FormulaCode D-5 is not appropriate in this record. If you are calculating SO2 from multiple fuels using Appendix D, you should report a formula with a FormulaCode of D-12 in the DHV record; otherwise, do not report a FormulaID.	12/22/2021 07	12/22/2021 11	5
				12/22/2021 23	12/23/2021 08	10
				12/24/2021 05	12/24/2021 08	4
				12/24/2021 18	12/24/2021 23	6
				12/25/2021 17	12/25/2021 20	4
				12/26/2021 08	12/26/2021 15	8
				12/27/2021 05	12/27/2021 07	3
				12/28/2021 03	12/28/2021 12	10
				12/29/2021 10	12/29/2021 13	4
				12/30/2021 06	12/30/2021 13	8
				12/31/2021 08	12/31/2021 12	5

Summary Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message
BW2	CRIT1	HOURAGG-7-E	The CurrentReportingPeriodTotal in the Summary Value record for NOXR could not be recalculated because of errors listed above.
		HOURAGG-8-E	The CurrentReportingPeriodTotal in the Summary Value record for NOXM could not be recalculated because of errors listed above.