



ECMPS Client Tool

Version 1.* 2022 Q2

Emissions Evaluation Report

June 29, 2022 02:26 PM

Facility Name: Gans Generating Facility

Facility Details

Facility ID (ORISPL): 55377
Monitoring Plan Location IDs: 8
State: PA
County: Fayette County
Year/Quarter: 2020 Q4
Total Hours: 2208

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

QA Status Errors

Unit/Stack/ Pipe	Category Description	Severity	Check Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
8	O2 Dry Daily Calibration Status Evaluation	CRIT1	OOC-Prior Online Test Failed	The prior online daily calibration test for Component ID 021, Span Scale H completed on 12-12-2020 at 18:06 failed.	12/13/2020 16	12/13/2020 16	1