



# ECMPS Client Tool

Version 1.\* 2022 Q2

## QA/Cert Test Evaluation Report

November 16, 2022 03:27 PM

**Facility Name:** Bethpage Energy Center

### Facility Details

Facility ID (ORISPL): 50292  
State: NY  
County: Nassau County

### Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
GT1	ONOFF	ONOF-Q12017-013-2 01/21/2017 18	013/NOX	CRIT1	<a href="#">ONOFF-3-A</a>	You did not provide TestReasonCode, which is required for this test.
				INFORM	<a href="#">ONOFF-23-C</a>	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		ONOF-Q12017-032-1 01/21/2017 18	032/CO2	CRIT1	<a href="#">ONOFF-4-A</a>	You did not provide UpscaleGasLevelCode, which is required for this test.
				INFORM	<a href="#">ONOFF-23-C</a>	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
					<a href="#">ONOFF-28-A</a>	The software could not evaluate the online offline calibration test calculations reported for the offline upscale injection, because of the errors listed above.
					<a href="#">ONOFF-30-A</a>	The software could not evaluate the online offline calibration test calculations reported for the online upscale injection, because of the errors listed above.