



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

November 18, 2022 05:18 PM

Facility Name: Crystal River

Facility Details

Facility ID (ORISPL): 628
State: FL
County: Citrus County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
1GTA	CYCLE	C11A-CHNOX-0119 01/23/2019 12:27	001/BGFF	CRIT1	CYCLE-2-B	The component type code in the monitoring plan is BGFF. This type of component is not appropriate for a cycle time test.
					CYCLE-16-A	The cycle time test did not contain the correct number of injection records. There must be two records: one HIGH level gas injection and one ZERO level gas injection.
					TEST-9-A	You have not reported a valid monitoring plan span record that was active during the test.
					TEST-22-B	A Monitoring Plan associated with this test has not been evaluated. You must evaluate all active and future Monitoring Plans containing the location in this test in order to complete the evaluation of this test.
			INFORM		CYCLE-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.