



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

October 14, 2022 06:01 PM

Facility Name: Bethpage Energy Center

Facility Details

Facility ID (ORISPL): 50292
State: NY
County: Nassau County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
GT4	7DAY	7DAY-Q22018-206-1 06/18/2018 08:26	206/NOX	CRIT1	SEVNDAY-17-F	The Zero Calibration Error reported for Zero Injection Date 05/04/2018 is inconsistent with the recalculated calibration error for the gas injection or reference signal.
					SEVNDAY-23-A	The reference values are not consistent with the calibration gas/signal levels reported. The reference values of zero-level gas injections or signals must be less than those of upscale gas injections.
				CRIT2	SEVNDAY-24-A	The tag value of at least one Zero level reference signal or calibration gas for this test is 88.0%, which does not meet the performance specifications of 40 CFR Part 75. The concentration of the zero reference signal or calibration gas must be less than or equal to 20.0% of the span value. The test is invalid.
				INFORM	SEVNDAY-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		7DAY-Q32020-207-13 07/03/2020 02:26	207/NOX	CRIT1	SEVNDAY-18-F	The Upscale Calibration Error reported for Zero Injection Date 06/25/2020 is inconsistent with the recalculated calibration error for the gas injection or reference signal.
					SEVNDAY-27-D	You have reported a 7-day calibration test, but the recalculated results indicate a failing test.
				CRIT2	SEVNDAY-25-E	The tag value of at least one High level reference calibration gas for this test is 104.0%, which does not meet the applicable performance specifications. The concentration of the high reference calibration gas must be between 80.0% and 100.0% of the span value. The test is invalid.
				INFORM	SEVNDAY-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		7DAY-Q32020-208-5 07/03/2020 02:23	208/O2	CRIT1	SEVNDAY-7-B	The ZeroInjectionDate was not equal to the UpscaleInjectionDate for Zero Injection Date 06/25/2020. The zero-level and upscale injections reported in the same record must be performed on the same day.
					SEVNDAY-19-A	You reported a test Begin Date, Hour, and Minute that is not the same as the Injection Date, Hour, and Minute of the first injection in the 7-day calibration test.
					SEVNDAY-26-A	This test contains at least two zero-level calibration gas injections or reference signals that were performed on the same day.
				INFORM	SEVNDAY-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.