



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

October 14, 2022 06:00 PM

Facility Name: Bethpage Energy Center

Facility Details

Facility ID (ORISPL): 50292
State: NY
County: Nassau County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
GT1	7DAY	7DAY-Q22015-012-1 05/30/2015 09:51	012/NOX	INFORM	SEVNDAY-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		7DAY-Q22015-013-3 05/30/2015 09:51	013/NOX	CRIT1	SEVNDAY-6-A	The zero injection date, hour, and/or minute for Zero Injection Date 05/20/2015 is invalid.
				INFORM	SEVNDAY-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		7DAY-Q22015-031-2 05/30/2015 09:51	031/CO2	CRIT1	SEVNDAY-7-B	The ZeroInjectionDate was not equal to the UpscaleInjectionDate for Zero Injection Date 05/20/2015. The zero-level and upscale injections reported in the same record must be performed on the same day.
				INFORM	SEVNDAY-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		7DAY-Q22015-032-2 05/30/2015 09:51	032/CO2	CRIT1	SEVNDAY-8-A	You did not provide ZeroCalibrationError, which is required for Zero Injection Date 05/20/2015.
				INFORM	SEVNDAY-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.