



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

November 16, 2022 03:28 PM

Facility Name: Bethpage Energy Center

Facility Details

Facility ID (ORISPL): 50292
State: NY
County: Nassau County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
GT3	ONOFF	21Q2-NOXH-ONOFF 06/03/2021 16	310/NOX	CRIT1	ONOFF-8-A	You did not provide OfflineUpscaleCalibrationError, which is required for this test.
				INFORM	ONOFF-23-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		21Q2-NOXL-ONOFF 06/03/2021 16	310/NOX	CRIT1	ONOFF-7-B	You defined an invalid OfflineUpscaleReferenceValue for this test. This value must be greater than zero and less than 20,000.
				INFORM	ONOFF-23-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
					ONOFF-28-A	The software could not evaluate the online offline calibration test calculations reported for the offline upscale injection, because of the errors listed above.
		21Q2-O2-ONOFF 06/03/2021 16	320/O2	CRIT1	ONOFF-9-A	The Offline Zero injection Date and/or Hour is invalid.
				INFORM	ONOFF-35-C	You reported a value of "1" as the Online Zero APS Indicator for the test, but you must use the standard performance specification criteria for CO2 and O2 components.
					ONOFF-23-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		ONOF-Q12018-101-1 02/12/2018 18	101/NOX	CRIT1	ONOFF-10-A	You did not provide OfflineZeroMeasuredValue, which is required for this test.
				INFORM	ONOFF-23-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
					ONOFF-29-A	The software could not evaluate the online offline calibration test calculations reported for the offline zero-level injection, because of the errors listed above.
		ONOF-Q12018-105-1 02/12/2018 18	105/O2	CRIT1	ONOFF-11-A	You did not provide OfflineZeroReferenceValue, which is required for this test.
				INFORM	ONOFF-23-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
					ONOFF-29-A	The software could not evaluate the online offline calibration test calculations reported for the offline zero-level injection, because of the errors listed above.
		ONOF-Q42013-LK1-1 10/10/2013 17	LK1/O2	CRIT1	ONOFF-12-B	The value -1.00 in the field OfflineZeroCalibrationError for this test is not within the range of valid values. This value must be greater than or equal to zero.

Facility Name: Bethpage Energy Center

QA/Cert Test Evaluation Report

Facility ID (ORISPL): 50292

November 16, 2022 03:28 PM

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
GT3	ONOFF	ONOF-Q42013-LK1-1 10/10/2013 17	LK1/O2	INFORM	ONOFF-23-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.