



# ECMPS Client Tool

Version 1.\* 2022 Q2

## Emissions Evaluation Report

August 25, 2022 02:09 PM

Facility Name: Barry

### Facility Details

Facility ID (ORISPL): 3  
Monitoring Plan Location IDs: 5  
State: AL  
County: Mobile County  
Year/Quarter: 2021 Q3  
Total Hours: 2208

### Evaluation Results

#### General Errors

Severity	Check Code / Result	Result Message
INFORM	<a href="#">HOURGEN-13-B</a>	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

#### Hourly Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
5	CRIT1	<a href="#">MATSDHV-9-A</a>	You reported an MODC code that is not valid for the MATS DHV.	07/01/2021 16	07/01/2021 16	1
		<a href="#">MATSDHV-10-A</a>	You did not report a FormulaID in the MATS DHV record for HGRH.	07/01/2021 18	07/01/2021 18	1
	CRIT2	<a href="#">MATSDHV-17-D</a>	You reported an UnadjustedHourlyValue for a MATS DHV record, that is not reported if a valid concentration was not available or substitute data reported for one or more essential auxiliary parameters.	07/01/2021 17	07/01/2021 17	1
	INFORM	<a href="#">HOUROP-32-H</a>	Warning: The HourLoad reported in the Hourly Operating Data record is higher than the MaximumLoadValue in the Monitoring Load record reported in your monitoring plan. Sources are required to periodically (at least once annually) evaluate the appropriateness of these maximum values in the monitoring plan and make proper adjustments when necessary. You should investigate the cause of these exceedances and determine whether an adjustment to the MaximumLoadValue in your monitoring plan is necessary.	08/16/2021 12	08/16/2021 12	1
				09/13/2021 20	09/13/2021 20	1