



ECMPS Client Tool

Version 1.* 22 Q2 Build 1

Emissions Evaluation Report

May 24, 2022 12:45 PM

Facility Name: Crystal River

Facility Details

Facility ID (ORISPL): 628
Monitoring Plan Location IDs: 1GTB
State: FL
County: Citrus County
Year/Quarter: 2021 Q4
Total Hours: 2208

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

NSPS4T Summary Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message
1GTB	CRIT1	NSPS4T-2-A	You have reported NoCompliancePeriodEndedIndicator of 1, but have also reported compliance period data. This is incorrect.
		NSPS4T-3-C	You have not reported NSPS4T Fourth Quarter data. A fourth quarter file should contain this data.
	INFORM	NSPS4T-4-A	You reported an Electrical Load that is not consistent with the reported CO2 Emission Standard.