



# ECMPS Client Tool

Version 1.\* 2022 Q1

## Emissions Evaluation Report

March 21, 2022 12:18 PM

**Facility Name: Brandywine Power Facility**

### Facility Details

Facility ID (ORISPL): 54832  
Monitoring Plan Location IDs: 1  
State: MD  
County: Prince George's County  
Year/Quarter: 2014 Q3  
Total Hours: 2208

### Evaluation Results

#### General Errors

Severity	Check Code / Result	Result Message
INFORM	<a href="#">HOURGEN-13-B</a>	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

#### Hourly Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
1	CRIT1	<a href="#">HOURDHV-18-K</a>	You did not report a MonitoringSystemID in the DHV record for NOXR. This information is required when you report missing data.	07/07/2014 13	07/07/2014 13	1
				07/07/2014 21	07/07/2014 21	1
				07/08/2014 13	07/12/2014 13	97
				07/12/2014 15	07/12/2014 16	2
				07/22/2014 12	07/22/2014 12	1
				08/04/2014 09	08/04/2014 11	3
				08/04/2014 14	08/04/2014 14	1
				08/05/2014 05	08/05/2014 05	1
				08/06/2014 03	08/06/2014 03	1
				08/19/2014 06	08/19/2014 06	1
				08/25/2014 08	08/25/2014 14	7
				08/27/2014 09	08/27/2014 11	3
				09/06/2014 23	09/06/2014 23	1

Facility Name: Brandywine Power Facility

Facility ID (ORISPL): 54832

## Emissions Evaluation Report

March 21, 2022 12:18 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
1	CRIT1	<a href="#">HOURLDHV-24-K</a>	You did not report a FormulaID in the DHV record for NOXR.	07/07/2014 13	07/07/2014 13	1
				07/07/2014 21	07/07/2014 21	1
				07/08/2014 13	07/12/2014 13	97
				07/12/2014 15	07/12/2014 16	2
				07/22/2014 12	07/22/2014 12	1
				08/04/2014 09	08/04/2014 11	3
				08/04/2014 14	08/04/2014 14	1
				08/05/2014 05	08/05/2014 05	1
				08/06/2014 03	08/06/2014 03	1
				08/19/2014 06	08/19/2014 06	1
				08/25/2014 08	08/25/2014 14	7
				08/27/2014 09	08/27/2014 11	3
				09/06/2014 23	09/06/2014 23	1
		<a href="#">HOURLDHV-32-C</a>	You did not report an MHV record for NOXC for the hour. An MHV record is required for missing data.	07/07/2014 13	07/07/2014 13	1
				07/07/2014 21	07/07/2014 21	1
				07/08/2014 13	07/12/2014 13	97
				07/12/2014 15	07/12/2014 16	2
				07/22/2014 12	07/22/2014 12	1
				08/04/2014 09	08/04/2014 11	3
				08/04/2014 14	08/04/2014 14	1
				08/05/2014 05	08/05/2014 05	1
				08/06/2014 03	08/06/2014 03	1
				08/19/2014 06	08/19/2014 06	1
				08/25/2014 08	08/25/2014 14	7
				08/27/2014 09	08/27/2014 11	3
				09/06/2014 23	09/06/2014 23	1
	INFORM	<a href="#">HOURLCV-16-A</a>	The AdjustedHourlyValue in the DHV record for NOX could not be recalculated due to errors listed above.	07/12/2014 14	07/12/2014 14	1
				07/12/2014 17	07/15/2014 23	79

Facility Name: Brandywine Power Facility

Emissions Evaluation Report

Facility ID (ORISPL): 54832

March 21, 2022 12:18 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
1	INFORM	<a href="#">HOURCV-16-A</a>	The AdjustedHourlyValue in the DHV record for NOX could not be recalculated due to errors listed above.	07/21/2014 03	07/21/2014 21	19
				07/22/2014 07	07/22/2014 11	5
				07/22/2014 13	07/28/2014 22	154
				08/04/2014 04	08/04/2014 08	5
				08/04/2014 12	08/04/2014 13	2
				08/04/2014 15	08/04/2014 22	8
				08/05/2014 04	08/05/2014 04	1
				08/05/2014 06	08/05/2014 22	17
				08/06/2014 04	08/06/2014 21	18
				08/17/2014 05	08/19/2014 05	49
				08/19/2014 07	08/25/2014 07	145
				08/25/2014 15	08/26/2014 17	27
		<a href="#">HOURCV-25-A</a>	The BAF for NOX MonitoringSystemID 103 cannot be determined, because the prior RATA had critical errors or because of a RATA Status error listed on this report.	07/12/2014 14	07/12/2014 14	1
				07/12/2014 17	07/15/2014 23	79
				07/21/2014 03	07/21/2014 21	19
				07/22/2014 07	07/22/2014 11	5
				07/22/2014 13	07/28/2014 22	154
				08/04/2014 04	08/04/2014 08	5
				08/04/2014 12	08/04/2014 13	2
				08/04/2014 15	08/04/2014 22	8
				08/05/2014 04	08/05/2014 04	1
				08/05/2014 06	08/05/2014 22	17
				08/06/2014 04	08/06/2014 21	18
				08/17/2014 05	08/19/2014 05	49
				08/19/2014 07	08/25/2014 07	145
				08/25/2014 15	08/26/2014 17	27
		<a href="#">HOURCV-41-A</a>	The AdjustedHourlyValue in the DHV record for NOXR could not be recalculated due to errors listed above.	07/12/2014 14	07/12/2014 14	1
				07/12/2014 17	07/15/2014 23	79

Facility Name: Brandywine Power Facility

## Emissions Evaluation Report

Facility ID (ORISPL): 54832

March 21, 2022 12:18 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
1	INFORM	<a href="#">HOURCV-41-A</a>	The AdjustedHourlyValue in the DHV record for NOXR could not be recalculated due to errors listed above.	07/21/2014 03	07/21/2014 21	19
				07/22/2014 07	07/22/2014 11	5
				07/22/2014 13	07/28/2014 22	154
				08/04/2014 04	08/04/2014 08	5
				08/04/2014 12	08/04/2014 13	2
				08/04/2014 15	08/04/2014 22	8
				08/05/2014 04	08/05/2014 04	1
				08/05/2014 06	08/05/2014 22	17
				08/06/2014 04	08/06/2014 21	18
				08/17/2014 05	08/19/2014 05	49
				08/19/2014 07	08/25/2014 07	145
				08/25/2014 15	08/26/2014 17	27

### Audit Results

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message
1	INFORM	<a href="#">EMAUDIT-1-B</a>	You have reported hourly data using Like Kind component 'LK1' for 263 hour(s) this year. Please be aware that the use of like kind monitors is limited to less than 720 hours on an annual basis.