



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

November 19, 2022 04:33 PM

Facility Name: Lincoln Combustion Turbine

Facility Details

Facility ID (ORISPL): 7277
State: NC
County: Lincoln County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
5	FFACCTT	U05G-032919 03/29/2019 08:00	052/GFFM	CRIT1	FFACCTT-10-A	You did not provide HighLevelAccuracySpecCode, which is required for this test.
				INFORM	FFACCTT-4-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		U05G-052521 05/25/2021 08:00	052/GFFM	CRIT1	FFACCTT-9-B	The value -1.0 in the field HighLevelAccuracy for this test is not within the range of valid values. This value must be greater than or equal to zero.
				INFORM	FFACCTT-4-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.