



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

November 19, 2022 07:00 PM

Facility Name: Lincoln Combustion Turbine

Facility Details

Facility ID (ORISPL): 7277
State: NC
County: Lincoln County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
4	FFACC	U4O-072417 07/24/2017 11:00	041/OFFM	CRIT1	FFACC-8-B	The value -1.0 in the field LowFuelAccuracy for this test is not within the range of valid values. This value must be greater than or equal to zero.
				INFORM	FFACC-3-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		U4O-082119 08/21/2019 15:00	041/OFFM	CRIT1	FFACC-7-A	You did not provide AccuracyTestMethodCode, which is required for this test.
				INFORM	FFACC-3-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.