



# ECMPS Client Tool

Version 1.\* 2022 Q2

## QA/Cert Test Evaluation Report

November 19, 2022 06:59 PM

**Facility Name:** Lincoln Combustion Turbine

### Facility Details

Facility ID (ORISPL): 7277  
State: NC  
County: Lincoln County

### Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
2	FFACC	U2O-072417 07/24/2017 10:00	021/OFFM	CRIT1	<a href="#">FFACC-4-A</a>	You reported a ReinstallationDate and/or ReinstallationHour for an accuracy test that, according to the accuracy test method, was performed in-line.
				INFORM	<a href="#">FFACC-3-C</a>	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		U2O-082119 08/21/2019 14:00	021/OFFM	INFORM	<a href="#">FFACC-2-A</a>	The TestResultCode indicates that the test was aborted. If the test was aborted for a reason not related to monitor performance, you should not report the test.
					<a href="#">FFACC-3-C</a>	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.