



# ECMPS Client Tool

Version 1.\* 2022 Q2

## QA/Cert Test Evaluation Report

November 18, 2022 05:01 PM

Facility Name: Barry

### Facility Details

Facility ID (ORISPL): 3  
State: AL  
County: Mobile County

### Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
6A	CYCLE	1 05/01/2019 10:12	CO2/CO2	CRIT2	<a href="#">CYCLE-9-A</a>	The tag value of the 'ZERO' level calibration gas of the cycle time test data for Gas Level ZERO is 30 % of span and does not meet the performance specifications of 40 CFR Part 75 (or Part 63 as applicable). The concentration of the 'zero' reference calibration gas must be less than or equal to 20.0% of the span value reported in the monitoring plan.
				INFORM	<a href="#">CYCLE-5-C</a>	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
					<a href="#">TEST-21-A</a>	IMPORTANT FYI: This test was determined to be "INVALID" due to one or more Critical Level 2 errors. The reported data indicate that the test was not performed according to the requirements and therefore cannot be used to validate emissions data. Unless you make corrections to the test data and re-run the evaluation, this test will be disregarded by the emissions evaluation routine. If you are unable to eliminate the Critical Level 2 error(s) by correcting the test data but you believe this test should be considered valid, contact your CAMD analyst.
		2 05/01/2019 10:12	NX1/NOX	CRIT1	<a href="#">CYCLE-10-A</a>	You did not provide BeginMonitorValue, which is required for Gas Level ZERO.
				INFORM	<a href="#">CYCLE-5-C</a>	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.