



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

October 13, 2022 03:10 PM

Facility Name: Four Corners Steam Elec Station

Facility Details

Facility ID (ORISPL): 2442
Monitoring Plan Location IDs: 4
State: NM
County: San Juan County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
4	F2LCHK	87 2021 Q3	F43/CO2	CRIT1	F2LCHK-1-B	According to the monitoring system record, the monitoring system in this flow-to-load check was not a flow system.
					TEST-22-B	A Monitoring Plan associated with this test has not been evaluated. You must evaluate all active and future Monitoring Plans containing the location in this test in order to complete the evaluation of this test.