



ECMPS Client Tool

Version 1.* 22 Q2 Build 1

Emissions Evaluation Report

May 23, 2022 04:22 PM

Facility Name: R Gallagher

Facility Details

Facility ID (ORISPL): 1008
Monitoring Plan Location IDs: 4
State: IN
County: Floyd County
Year/Quarter: 2021 Q2
Total Hours: 2184

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

Sorbent Trap Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message
4	CRIT1	MATSTRP-8-C	The system reported for the sorbent trap does not span the period of the sorbent trap.
		MATSTRP-15-A	You reported sorbent trap Trap R26 at 06/01/2021 5:00:00 AM, but no sorbent trap methods are active during the period the trap is active.