



# ECMPS Client Tool

Version 1.\* 2022 Q2

## Emissions Evaluation Report

June 22, 2022 04:09 PM

### Facility Name: Theodore Cogeneration

#### Facility Details

Facility ID (ORISPL): 7721  
Monitoring Plan Location IDs: CC1  
State: AL  
County: Mobile County  
Year/Quarter: 2021 Q4  
Total Hours: 2208

### Evaluation Results

#### General Errors

Severity	Check Code / Result	Result Message
INFORM	<a href="#">HOURGEN-13-B</a>	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.
	<a href="#">HOURGEN-14-A</a>	You reported one or more daily calibration tests that will not fulfill your daily calibration testing requirement, because these tests were performed while the unit was not operating and you have not reported a prior online-offline calibration demonstration. These tests have been assigned a CalculatedTestResult of "IGNORED", and they can be viewed on the Daily Calibration tab of the View Detailed Emissions Screen. If you intend to use offline tests to fulfill your daily calibration testing requirement, you must conduct an online-offline calibration demonstration.

#### Hourly Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
CC1	INFORM	<a href="#">HOUROP-56-A</a>	MODC 46 was reported for the NOx Concentration monitor value which requires reporting MODC 46 for the CO2 Concentration monitor value, but MODC 01 was reported.	11/07/2021 06	11/07/2021 09	4
				11/07/2021 11	11/07/2021 11	1