



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

November 18, 2022 05:03 PM

Facility Name: Barry

Facility Details

Facility ID (ORISPL): 3
State: AL
County: Mobile County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
7B	CYCLE	3 02/03/2020 12:11	CD1/CO2	CRIT1	CYCLE-15-A	The calibration gas values were not consistent with the calibration gas levels reported. The reference value of the zero-level gas injection must be less than that of the high-level gas injection.
				CRIT2	CYCLE-9-A	The tag value of the 'ZERO' level calibration gas of the cycle time test data for Gas Level ZERO is 90.3 % of span and does not meet the performance specifications of 40 CFR Part 75 (or Part 63 as applicable). The concentration of the 'zero' reference calibration gas must be less than or equal to 20.0% of the span value reported in the monitoring plan.
				INFORM	CYCLE-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		4 02/03/2020 12:11	NX1/NOX	CRIT1	CYCLE-13-A	You reported a test Begin Date, Hour, and Minute that is not the same as the Begin Date, Hour, and Minute of the first injection in the cycle time test.
					CYCLE-16-A	The cycle time test did not contain the correct number of injection records. There must be two records: one HIGH level gas injection and one ZERO level gas injection.
				INFORM	CYCLE-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.