



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

October 12, 2022 04:19 PM

Facility Name: Lincoln Combustion Turbine

Facility Details

Facility ID (ORISPL): 7277
State: NC
County: Lincoln County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
11	APPE	11NOX2016-1 02/24/2016 15:43	410/NOXE	CRIT1	APPE-41-A	The AverageHourlyHeatInputRate reported for Operating Level 1 is inconsistent with the value recalculated from the run and fuel data for the operating level.
				INFORM	APPE-4-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		11NOX2016-2 02/25/2016 17:45	400/NOXE	CRIT1	APPE-39-A	This test included one or more runs with an HourlyHeatInputRate which is greater than or equal to the HourlyHeatInputRate for a run for a higher operating level.
					APPE-41-A	The AverageHourlyHeatInputRate reported for Operating Level 1 is inconsistent with the value recalculated from the run and fuel data for the operating level.
					APPE-44-A	The HourlyHeatInputRate for Operating Level 1 Run Number 1 does not correspond to the hourly heat input rate recalculated from the start and end times and heat input derived from the Appendix E gas and oil records.
				INFORM	APPE-4-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		11NOX2021-1 02/24/2021 14:31	410/NOXE	CRIT1	APPE-10-A	You reported a test BeginDate, BeginHour, and BeginMinute that is not the same as the BeginDate, BeginHour, and BeginMinute of the first run in the Appendix E test.
					APPE-42-A	You have included Appendix E runs at fewer than four operating levels. Appendix E tests for units subject to Part 75 must be performed at at least four operating levels.
				INFORM	APPE-4-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		11NOX2021-2 02/25/2021 14:42	400/NOXE	CRIT1	APPE-34-B	You defined an invalid GasVolume for Operating Level 1 Run Number 1 Gas System ID 200. This value must be greater than zero and less than 20,000.
					APPE-35-B	You defined an invalid GasGCV for Operating Level 1 Run Number 1 Gas System ID 200. This value must be greater than zero and less than 20,000.
					APPE-36-B	You defined an invalid GasHeatInput for Operating Level 1 Run Number 1 Gas System ID 200. This value must be greater than zero and less than 20,000.
					APPE-43-A	You have defined an inconsistent number of fuel flow records for this test. There must be the same combination of supporting fuel flow records for each run.
				INFORM	APPE-4-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.