



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

November 19, 2022 06:58 PM

Facility Name: Lincoln Combustion Turbine

Facility Details

Facility ID (ORISPL): 7277
State: NC
County: Lincoln County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
1	FFACC	U1O-072417 07/24/2017 10:00	011/CO2	CRIT1	FFACC-1-B	The component type in the monitoring plan is CO2. This type of component does not require a fuel flow accuracy test. Only component types 'OFFM' or 'GFFM' may have a fuel flow accuracy test.
					TEST-22-B	A Monitoring Plan associated with this test has not been evaluated. You must evaluate all active and future Monitoring Plans containing the location in this test in order to complete the evaluation of this test.
				INFORM	FFACC-3-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		U1O-082119 08/21/2019 13:00	011/CO2	CRIT1	FFACC-1-B	The component type in the monitoring plan is CO2. This type of component does not require a fuel flow accuracy test. Only component types 'OFFM' or 'GFFM' may have a fuel flow accuracy test.
					TEST-22-B	A Monitoring Plan associated with this test has not been evaluated. You must evaluate all active and future Monitoring Plans containing the location in this test in order to complete the evaluation of this test.
				INFORM	FFACC-3-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.